



## **APPENDIX B**

### Summary of Dry Weather Screening Results

951 records with flow  $\neq$  zero  
& prior to 07/01/01

# Dry Weather Screening Data

Outfall Permit Year	Date	Visit #	Flow ?	Flow Rate (gpm)	pH (su)	Chlorine (ppm)	Copper (ppm)	Phenol (ppm)	Detergents (ppm)	Ammonia (ppm)	Fecal Sample (mpn/100ml)	Turbidity (ntu)	Color	Odor?	Surface Scum	Oil Sheen
<b>00-100-0300</b>																
1992	2/5/92	1	Yes	44	7.9	0	0	0	< 0.25		Yes 19	0	0	No	No	No
	2/5/92	2	Yes	44	7.9	0	0	0	< 0.25		No	0	10	No	No	No
1997	2/18/97	1	Yes	10	7.0	0.25	0	0	0.20	1.50	Yes 30,000	10	0	No		No
	2/19/97	2	Yes	10	7.8	0.10	0	0	0.30	0.80	No	0	0	No	No	No
1998	2/27/97	3	Yes	10	7.5	0.25	0	0	0.10	0.50	No	0	0	No	No	No
	2/27/97	4	Yes	10	7.8	0.25	0	0	0	0.70	No	0	0	No	No	No
	7/15/97	1	Yes	70	7.0	0	0	0	0.20	0.40	No	20	15	No	No	No
	7/15/97	2	Yes	70	7.1	0	0	0	0.20	0.60	No	20	20	No	No	No
	9/2/97	3	Yes	50	7.3	0	0	0	0.20	0.30	No	20	15	No	No	No
	9/2/97	4	Yes	50	7.1	0	0	0	0.10	0.40	No	20	20	No	No	No
1999	9/24/98	1	Yes	19	7.0	0.05	0	0	0.25	2.00	Yes 240,000	50	5	No	No	No
	9/24/98	2	Yes	19	7.0	0.20	0	0	0.10	3.00	No	20	5	No	No	No
	12/15/98	3	Yes	5	7.7	0.20	0	0	0	0.10	No	0	0	No	No	No
	12/15/98	4	Yes	5	7.7	0.30	0	0	0.10	0.10	No	0	0	No	No	No
2000	7/19/99	1	Yes	5	7.7	0	0	0	0	0	No	0	0	No	No	No
	7/19/99	2	Yes	4	7.7	0.10	0	0	0	0	No	0	0	No	No	No
	8/23/99	3	Yes	60	8.2	0	0	0	0	0	No	0	0	No	No	No
	8/23/99	4	Yes	60	7.8	0	0	0	0	0	No	0	0	No	No	No
2001	7/17/00	1	Yes	13	8.2	0.30	0	0	0	0	No	0	20	No	No	No
	7/17/00	2	Yes	13	8.2	0.40	0	0	0	0.30	No	0	0	No	No	No
	8/17/00	3	Yes	10	8.2	0.30	0	0	0	0.10	No	0	0	No	No	No
	8/17/00	4	Yes	10	7.8	0.40	0	0	0	0.10	No	0	20	No	No	No
<b>00-300-0285</b>																
1997	11/5/96	1	Yes	TRICKLE	6.4	0	0		> 3		Yes 590,000	75	40	CHEMICAL		Yes
	11/6/96	2	Yes	TRICKLE	6.7	0	0		> 3		No	100	38	SEWAGE		Yes
	12/3/96	3	Yes	2	8.0	0	0.10	0	0.20	0.10	No	0	0	No	No	No
	12/4/96	4	Yes	2	7.9	0	0.10	0	0.15	0.10	No	0	0	No	No	No
1998	8/26/97	3	Yes	15	6.5	0	0	0.10	> 3	> 10.00	Yes > 60,000	1,000	50	SEWAGE		No
	8/26/97	4	Yes	20	6.6	0.05	0	0	3	10.00	No	1,000	50	SEWAGE		No
2001	10/17/00	1	Yes	75	7.5	0	0	0	0	0	No	0	0	No	No	No
	10/17/00	2	Yes	75	7.0	0	0	0	0	0	No	0	0	No	No	No
	11/28/00	3	Yes	75	7.0	0.20	0	0	1.50	0	No	0	10	No	No	No
	11/28/00	4	Yes	75	7.0	0	0	0	0	0	No	0	0	No	No	No

Outfall Permit Year	Date	Visit #	Flow ?	Flow Rate (gpm)	pH (su)	Chlorine (ppm)	Copper (ppm)	Phenol (ppm)	Detergents (ppm)	Ammonia (ppm)	Fecal Sample (mpn/100ml)	Turbidity (ntu)	Color	Odor?	Surface Scum	Oil Sheen
<b>00-300-0385</b>																
1992	2/3/92	1	Yes	4	7.8	0	0	0.25	0.40		No	< 50	40	No	No	No
	2/4/92	2	Yes	4	7.8	0	0	0.15	0.25		Yes > 60,000	< 50	25	No	No	No
1997	10/10/96	1	Yes	SLIGHT	7.6	0	0	0.40	0.20		Yes 460,000	100	20	SEWAGE	No	No
	10/11/96	2	Yes	TRICKLE	7.3	0	0	0.10	0.20		No	50	5	SEWAGE	No	No
	11/20/96	3	Yes	8	7.3	0	0	0.30	0.75	> 10.00	No	75	50	SEWAGE	No	No
2000	11/22/96	4	Yes	0.80	7.5	0	0	0	0.25	5.00	Yes 21,000	0	10	SEWAGE	No	No
	1/12/00	1	Yes	0.63	7.8	0.80	0	0	3	2.00	Yes 54,000	0	0	No	No	No
	1/12/00	2	Yes	0.63	7.8	0.30	0	0	2	2.00	No	0	0	No	No	No
	2/16/00	3	Yes	0.32	7.8	1.50	0	0	3	1.00	Yes 0	0	30	No	No	No
	2/16/00	4	Yes	0.32	7.8	0.80	0	0	3	1.00	No	0	0	No	No	No
<b>00-300-0460</b>																
2000	2/16/00	4	Yes	0.50	7.6	0	0	0	0.50	0	No	50	0	No	No	No
<b>00-400-0330</b>																
1999	12/15/98	4	Yes	0.13		3.50	0	0	0	0	No	0	0	No	No	No
<b>01-100-0155</b>																
1997	5/7/97	1	Yes	15	7.8	0	0	0	0.10	0.50	No	10	0	MUSTY	No	No
	5/7/97	2	Yes	15	7.3	0	0	0	0.10	0.40	No	0	0	No	No	No
	6/24/97	3	Yes	10	7.3	0	0	0	0.10	0.70	No	20	0	DEATH	No	No
	6/24/97	4	Yes	10	7.1	0	0	0	0.10	0.30	No	20	0	DEATH	No	No
1998	5/15/98	1	Yes	LOW	9.0	0.20	0	0	0	0.10	No	0	0	No	No	No
	5/15/98	2	Yes	LOW	8.8	0	0	0	0	0	No	0	0	No	No	No
	6/24/98	3	Yes	0.50	8.2	0.30	0	0	0	0	No	0	0	No	No	No
	6/24/98	4	Yes	0.50	8.1	0	0	0	0	0	No	0	0	No	No	No
1999	10/12/98	2	Yes	0.04	7.2	0.10	0	0	0	0	No	0	20	No	FOAM	No
	12/15/98	3	Yes	0.34	8.9	0.40	0	0	0	0	No	0	0	No	No	No
	12/15/98	4	Yes	0.34		0	0	0	0	0.10	No	0	0	No	No	No
2000	7/19/99	1	Yes	1	8.0	0.30	0	0	0	0	No	0	0	No	No	No
	7/19/99	2	Yes	1	8.0	0.10	0	0	0	0	No	0	0	No	No	No
	8/23/99	3	Yes	0.80	8.0	0.10	0	0	0	0	No	0	0	No	No	No
2001	7/18/00	1	Yes	0.04	8.0	0.30	0	0	0	0	No	0	0	No	No	No
	7/18/00	2	Yes	0.08	8.0	0.30	0	0	0	0	No	0	0	No	No	No
	8/25/00	3	Yes	0.16	8.0	0.10	0	0	0	0	No	0	0	No	No	No
	8/25/00	4	Yes	0.08	8.2	0.20	0	0	0	0	No	0	0	No	No	No

Outfall Permit Year	Date	Visit #	Flow ?	Flow Rate (gpm)	pH (su)	Chlorine (ppm)	Copper (ppm)	Phenol (ppm)	Detergents (ppm)	Ammonia (ppm)	Fecal Sample (mpn/100ml)	Turbidity (ntu)	Color	Odor?	Surface Scum	Oil Sheen
<b>01-100-0230</b>																
1998	2/26/98	1	Yes	2	<u>8.4</u>	0	0	0	<u>0.50</u>	<u>2.00</u>	Yes <u>430,000</u>	100	70	No	GREEN	No
	2/26/98	2	Yes	2	<u>8.3</u>	0	0	0	<u>0.50</u>	<u>1.50</u>	No	100	60	No	GREEN	No
	3/30/98	3	Yes	1	<u>8.2</u>	0	0	0	0.20	0.80	No	100	50	SLIGHT	GREEN	No
	3/30/98	4	Yes	1	<u>8.6</u>	0	0	0	<u>0.50</u>	<u>1.50</u>	No	100	50	SLIGHT	GREEN	No
1999	10/16/98	1	Yes	19	7.5	0.10	0	0	0	0.10	No	0	0	No	No	No
	10/16/98	2	Yes	19	7.5	0.10	0	0	0	0	No	0	0	No	No	No
2000	7/26/99	1	Yes	2	7.6	0.20	<u>0.20</u>	0	0	0.40	No	50	100	No	No	No
	7/26/99	2	Yes	2	7.0	0.20	0	0	0	0.40	No	0	30	No	No	No
2001	8/30/99	3	Yes	5	7.4	<u>0.30</u>	<u>0.10</u>	0	<u>0.50</u>	<u>5.00</u>	Yes <u>117,016</u>	0	60	No	No	No
	8/30/99	4	Yes	29	7.4	0	0	0	0	<u>2.00</u>	No	0	0	No	No	No
	7/21/00	1	Yes	0.16	7.8	0	0	0	<u>0.50</u>	<u>9.00</u>	Yes	50	60	No	No	No
	7/21/00	2	Yes	0.16	8.0	0.20	0	0	<u>0.75</u>	<u>10.00</u>	No	25	60	SEWAGE	No	No
<b>01-100-0280</b>																
1999	10/21/98	1	Yes	4	7.8	<u>2.00</u>	0	0	0	0	No	0	0	No	No	No
	10/21/98	2	Yes	4	8.0	<u>2.50</u>	0	0	0	0	No	0	0	No	No	No
2000	1/11/99	3	Yes	4	7.6	0	0	0	0	0	No	0	0	No	No	No
	1/11/99	4	Yes	4	7.7	0	0	0	0	0	No	0	0	No	No	No
	7/26/99	1	Yes	60	7.4	0.10	0	0	0	0	No	0	20	No	No	No
	7/26/99	2	Yes	60	7.4	0.10	0	0	0	0	No	0	20	No	No	No
	8/30/99	3	Yes	12	<u>8.2</u>	0	0	0	0	0	No	0	0	No	No	No
	8/30/99	4	Yes	12	<u>8.2</u>	0	0	0	0	0	No	0	0	No	No	No
<b>01-100-0550</b>																
1992	11/14/91	1	Yes	4							No			No	No	No
<b>01-100-0560</b>																
1992	11/14/91	1	Yes	4	<u>8.2</u>	0	0	0	<u>&lt; 0.25</u>		No	0	40	No	No	No
	11/15/91	2	Yes	4	<u>8.4</u>	0.15	0	0	<u>&lt; 0.25</u>		Yes 10	< 50	30	No	No	No

Outfall Permit Year	Date	Visit #	Flow ?	Flow Rate (gpm)	pH (su)	Chlorine (ppm)	Copper (ppm)	Phenol (ppm)	Detergents (ppm)	Ammonia (ppm)	Fecal Sample (mpn/100ml)	Turbidity (ntu)	Color	Odor?	Surface Scum	Oil Sheen
<b>01-100-0660</b>																
1992	11/14/91	1	Yes	4	<u>8.2</u>	< 0.10	0	0	0		No	0	20	No	No	No
	11/15/91	2	Yes	4	<u>8.2</u>	0	0	0	0		Yes 60	0	20	No	No	No
1997	2/19/97	1	Yes	YES		0.10	0	0	<u>&gt; 3</u>	0.10	No	0	0	No	No	No
	2/19/97	2	Yes	YES		<u>0.30</u>	0	0	<u>0.25</u>	0.10	No	0	0	No	No	No
	4/10/97	3	Yes	YES	7.5	0	0	0	<u>0.25</u>	0	No	0	0	No	No	No
	4/10/97	4	Yes	YES	7.5	0	0	0	<u>&lt; 0.25</u>	0	No	0	1	No	No	No
1998	9/15/97	1	Yes	5	<u>8.5</u>	0	0	0	0.20	0.20	No	50	0	No	No	Yes
	9/15/97	2	Yes	5	<u>8.3</u>	0	0	0	<u>0.75</u>	0.10	No	50	0	No	POLLEN	No
	10/13/97	3	Yes	10	6.8	0	0	0	0.10	0.10	No	100	50	No	No	No
	10/13/97	4	Yes	10	7.1	0	0	0	0.10	0.10	No	75	40	No	No	No
<b>01-100-0775</b>																
1997	2/20/97	1	Yes	STEADY		0	<u>0.10</u>	<u>0.10</u>	<u>0.25</u>	0.20	Yes <u>2,100</u>	50	45	No		No
	2/20/97	2	Yes	STEADY	<u>8.2</u>	0.20	0	0	<u>0.25</u>	0.20	No	50	20	No		No
<b>01-100-0920</b>																
1992	11/18/91	1	Yes	4	7.3	0.10	<u>&lt; 0.10</u>	<u>0.15</u>	<u>&gt; 3</u>		No	75	20	No	No	No
1997	2/24/97	1	Yes	YES	<u>8.2</u>	<u>0.40</u>	0	<u>0.10</u>	<u>&gt; 3</u>	0.40	Yes <u>230</u>	0	20	No		No
	2/25/97	2	Yes	YES	<u>8.2</u>	0.10	<u>0.10</u>	<u>0.10</u>	<u>0.25</u>	0.20	No	0	0	No	No	No
	4/3/97	3	Yes	SLOW	7.0	0.10	0	0	<u>&gt; 3</u>		No	25	5	No	No	Yes
	4/3/97	4	Yes	YES	<u>9.0</u>	<u>0.50</u>	<u>0.60</u>	0	<u>3</u>	<u>1.00</u>	No	750	12	SOAP	No	No
1998	9/15/97	1	Yes	MINIMAL	7.0	<u>0.30</u>	<u>0.10</u>	0	<u>&gt; 3</u>	<u>1.00</u>	No	500	80	No	BUBBLES	No
	9/15/97	2	Yes	MINIMAL	7.2	0	<u>0.10</u>	0	<u>&gt; 3</u>	<u>1.20</u>	No	500	80	No	BUBBLES	No
	10/13/97	4	Yes	MINIMAL	7.0	<u>0.40</u>	0	<u>0.20</u>	<u>&gt; 3</u>	<u>3.00</u>	No	1,000	100	DETERGEN		No

Outfall Permit Year	Date	Visit #	Flow ?	Flow Rate (gpm)	pH (su)	Chlorine (ppm)	Copper (ppm)	Phenol (ppm)	Detergents (ppm)	Ammonia (ppm)	Fecal Sample (mpn/100ml)	Turbidity (ntu)	Color	Odor?	Surface Scum	Oil Sheen
<b>01-300-0060</b>																
1992	11/13/91	1	Yes	4	<u>8.1</u>	0	<u>&lt; 0.10</u>	0	<u>&lt; 0.25</u>		No	< 50	25	No	No	No
	11/13/91	2	Yes	4	<u>8.5</u>	0	0	0	<u>0.40</u>		Yes 590	0	10	No	No	No
1997	10/24/96	1	Yes	SLIGHT	7.9	0	0	0	<u>0.25</u>		Yes 500	0	0	No	No	No
	10/25/96	2	Yes	SLIGHT	7.9	0	0	0	0.20		No	0	0	No	No	No
	12/3/96	3	Yes	0.40	7.6	0	0	0	0.10	0.80	No	0	0	No		No
	12/4/96	4	Yes	0.40	<u>8.2</u>	0	0	0	0.20	<u>1.00</u>	Yes 73	0	50	SEWAGE		No
2000	10/27/99	1	Yes	0.84	7.6	0	0	0	0	0	No	0	0	No	No	No
	10/27/99	2	Yes	1	7.4	0.20	0	0	0	<u>4.00</u>	No	0	0	No	No	No
	12/2/99	3	Yes	0.95	7.7	0.20	0	0	0	0.20	No	0	20	No	No	No
	12/2/99	4	Yes	0.95	7.7	0	0	0	0	0.80	No	0	0	No	No	No
2001	7/17/00	1	Yes	1	7.8	0	0	0	0	0	No	0	0	No	No	No
	7/17/00	2	Yes	2	7.8	<u>0.40</u>	0	0	0	0.40	No	0	0	No	No	No
	8/17/00	3	Yes	1	7.8	<u>0.30</u>	0	0	0	0	No	0	0	No	No	No
	8/17/00	4	Yes	0.90	<u>8.2</u>	<u>0.30</u>	0	0	0	0	No	0	0	No	No	No
<b>01-300-0070</b>																
1992	11/13/91	1	Yes	942	7.9	0	0	0	0		No	0	15	No	No	No
	11/13/91	2	Yes	942	<u>8.2</u>	< 0.10	0	<u>&lt; 0.10</u>	0		Yes 20	0	0	No	No	No
1997	2/17/97	1	Yes	10	<u>8.4</u>	0.05	0	0	0.10	0.20	Yes 567	0	0	No		No
	2/17/97	2	Yes	10	<u>8.7</u>	0.05	0	0	<u>0.40</u>	<u>1.50</u>	No	0	0	No		No
	3/21/97	3	Yes	10	<u>8.1</u>	<u>1.50</u>	0	0	0	0	No	0	20	No		No
	3/21/97	4	Yes	10	<u>8.1</u>	<u>1.00</u>	0	0	0	<u>2.50</u>	Yes 5	0	20	No		No
2000	10/26/99	1	Yes	50	7.4	0	0	0	0	0.60	No	0	0	No	No	No
	10/26/99	2	Yes	50	7.6	<u>0.60</u>	0	0	0	0	No	0	0	No	No	No
	11/29/99	3	Yes	600	7.8	<u>0.60</u>	0	0	<u>0.50</u>	0	No	0	0	No	No	No
	11/29/99	4	Yes	600	7.4	0	0	0	0	0	No	0	0	No	No	No
2001	7/17/00	1	Yes	100	7.8	<u>0.40</u>	0	0	0	0.60	No	0	0	No	No	No
	7/17/00	2	Yes	100	<u>8.2</u>	0	0	0	0	0.60	No	0	0	No	No	No
	8/17/00	3	Yes	150	7.8	0.20	0	0	0	0.40	No	0	20	No	No	No
	8/17/00	4	Yes	150	<u>8.2</u>	<u>0.30</u>	0	0	0	0.60	No	0	0	No	No	No
<b>01-300-0095</b>																
1992	3/3/92	1	Yes	4	7.0	0	0	<u>3.50</u>	<u>1</u>		Yes 110	200	500	No	No	No
	3/4/92	2	Yes	4	7.4	0	0.05	<u>0.15</u>	<u>0.75</u>		No	75	500	No	No	No

Outfall Permit Year	Date	Visit #	Flow ?	Flow Rate (gpm)	pH (su)	Chlorine (ppm)	Copper (ppm)	Phenol (ppm)	Detergents (ppm)	Ammonia (ppm)	Fecal Sample (mpn/100ml)	Turbidity (ntu)	Color	Odor?	Surface Scum	Oil Sheen
<b>01-300-0150</b>																
1992	11/13/91	1	Yes	4	<u>8.1</u>	< 0.10	0	0	<u>&gt; 3</u>		No	0	0	No	No	No
	11/14/91	2	Yes	4	<u>8.4</u>	< 0.10	0	0	<u>1</u>		Yes <u>1,900</u>	0	10	No	No	No
1997	10/24/96	1	Yes	STEADY	<u>8.4</u>	0	0	0	0.10		Yes <u>2,000</u>	0	0	No	No	No
	10/25/96	2	Yes	STEADY	<u>8.3</u>	0	0	0	0.20		No	0	0	No	No	No
	12/3/96	3	Yes	50	<u>8.1</u>	0	<u>0.10</u>	0	0.20	0.10	No	0	0	SEWAGE	No	No
1998	12/4/96	4	Yes	STRONG	<u>8.3</u>	0	0	0	0.10	0.10	No	0	0	No	No	No
	5/15/98	1	Yes	MODER.	<u>9.1</u>	<u>1.00</u>	0	0	0.22	0.10	No	0	0	No	No	No
	5/15/98	2	Yes	MODER.	<u>8.9</u>	0.10	0	0	0	0.10	No	0	0	No	No	No
	6/24/98	3	Yes	2	<u>8.5</u>	0	0	0	0	0.10	No	0	15	No	No	No
	6/24/98	4	Yes	3	<u>8.4</u>	0.10	0	0	0	0	No	0	0	No	No	No
1999	10/12/98	1	Yes	13	7.3	0.20	0	0	0	0	No	0	0	No	No	No
	10/12/98	2	Yes	13	7.4	0	0	0	0.10	0	No	0	0	No	No	No
	12/15/98	3	Yes	11	<u>8.4</u>	0.10	0	0	0	0.20	No	0	0	No	No	No
	12/15/98	4	Yes	11		0	0	0	0	0	No	0	0	No	No	No
2000	7/19/99	1	Yes	6	7.6	0	0	0	<u>0.25</u>	0.20	No	0	30	No	No	No
	7/19/99	2	Yes	2	7.8	0.10	0	0	0	0	No	0	0	No	No	No
	8/23/99	3	Yes	2	8.0	0	0	0	0	0	No	0	0	No	No	No
	8/23/99	4	Yes	2	8.0	<u>0.30</u>	0	0	0	0	No	0	0	No	No	No
2001	7/18/00	1	Yes	0.90	7.8	0	0	0	0	0	No	0	0	No	No	No
	7/18/00	2	Yes	2	7.8	0.10	0	0	0	0	No	0	0	No	No	No
	8/25/00	3	Yes	3	<u>8.2</u>	0.10	0	0	0	0.60	No	0	0	No	No	No
	8/25/00	4	Yes	3	7.8	0.10	0	0	0	0.20	No	0	0	No	No	No
<b>01-300-0160</b>																
2000	10/22/99	1	Yes	5	7.4	<u>1.00</u>	0	0	0	0	No	0	0	No	No	No
	10/27/99	2	Yes	5	7.3	<u>1.00</u>	0	0	0	0	No	0	0	No	No	No
	11/30/99	3	Yes	5	7.4	<u>0.60</u>	0	0	0	0	No	0	0	No	No	No
	11/30/99	4	Yes	5	7.6	<u>0.60</u>	0	0	0	0	No	0	0	No	No	No
2001	7/21/00	1	Yes	5	7.8	<u>0.60</u>	0	0	0	0	No	0	0	No	No	No
	7/21/00	2	Yes	6	7.8	<u>0.60</u>	0	0	0	0	No	0	0	No	No	No
	8/25/00	3	Yes	4	7.8	<u>0.40</u>	0	0	0	0	No	0	30	No	No	No
	8/25/00	4	Yes	4	7.8	<u>0.60</u>	0	0	0	0	No	0	0	No	No	No

Outfall Permit Year	Date	Visit #	Flow ?	Flow Rate (gpm)	pH (su)	Chlorine (ppm)	Copper (ppm)	Phenol (ppm)	Detergents (ppm)	Ammonia (ppm)	Fecal Sample (mpn/100ml)	Turbidity (ntu)	Color	Odor?	Surface Scum	Oil Sheen
<b>01-300-0200</b>																
1992	11/13/91	1	Yes	4	7.7	<u>1.80</u>	0	0	<u>&lt; 0.25</u>		No	< 50	15	No	No	No
	11/14/91	2	Yes	4	7.8	<u>1.80</u>	0	0	<u>&lt; 0.25</u>		Yes 0	0	5	No	No	No
1997	2/18/97	1	Yes	STEADY		<u>2.00</u>	0	0	<u>0.25</u>	0.60	Yes < 1	0	0	No	No	No
	2/18/97	2	Yes	STEADY		<u>1.00</u>	0	0	<u>0.25</u>	0	No	0	0	No	No	No
	4/8/97	3	Yes	YES	7.0	<u>2.00</u>	0	0	<u>0.25</u>	0	No	0	0	No	No	No
	4/8/97	4	Yes	YES	7.0	<u>3.00</u>	0	0	0	0	No	0	3	No	No	No
1998	5/13/98	1	Yes	SLOW	7.8	0	0	0	0.20	0.30	No	0	25	No	CLOUDY	No
	5/13/98	2	Yes	SLOW	7.8	0	0	0	0	<u>1.00</u>	No	25	35	No	CLOUDY	No
	6/24/98	3	Yes	YES	7.6	0	0	0	0	0.30	No	0	0	No	No	No
	6/24/98	4	Yes	YES	<u>8.3</u>	<u>1.50</u>	0	0	<u>0.25</u>	0	No	0	0	No	No	No
<b>01-300-0350</b>																
1992	11/14/91	1	Yes	4	<u>12.1</u>	0	0	0	<u>0.40</u>		Yes 0	> 1,000	130	No	No	No
	11/15/91	2	Yes	4							No			No	No	No
2001	10/24/00	1	Yes	20	6.8	0	0	0	0	0	No	0	20	No	No	No
	10/24/00	2	Yes	20	6.5	0	0	0	0	0	No	0	20	No	No	No
	12/5/00	3	Yes	60	6.0	<u>0.40</u>	0	0	0	0	No	0	0	No	No	No
	12/5/00	4	Yes	60	6.0	0	0	0	0	0	No	0	0	No	No	No
<b>01-300-0395</b>																
1992	3/4/92	1	Yes	4	<u>8.2</u>	0	0	0	0		Yes 20	0	0	No	No	No
	3/4/92	2	Yes	4	<u>8.2</u>	0	0	0	0		No	0	0	No	No	No
<b>01-300-0520</b>																
1992	3/4/92	1	Yes	4	<u>8.9</u>	0	0	0	0		Yes 9	0	0	No	No	No
	3/4/92	2	Yes	4	<u>8.3</u>	0.05	0	0	0		No	0	0	No	No	No
<b>01-400-0170</b>																
1999	10/12/98	1	Yes	6	7.8	<u>2.50</u>	0	0	0	0.10	No	0	0	No	No	No
	10/12/98	2	Yes	6	7.8	<u>3.50</u>	0	0	0	0.10	No	0	0	No	No	No

<b>Outfall Permit Year</b>	<i>Date</i>	<i>Visit #</i>	<i>Flow ?</i>	<i>Flow Rate (gpm)</i>	<i>pH (su)</i>	<i>Chlorine (ppm)</i>	<i>Copper (ppm)</i>	<i>Phenol (ppm)</i>	<i>Detergents (ppm)</i>	<i>Ammonia (ppm)</i>	<i>Fecal Sample (mpn/100ml)</i>	<i>Turbidity (ntu)</i>	<i>Color</i>	<i>Odor?</i>	<i>Surface Scum</i>	<i>Oil Sheen</i>
<b>01-400-0250</b>																
1999	10/16/98	1	Yes	38	7.2	0.20	0	0	0	0	No	0	0	No	No	No
	10/16/98	2	Yes	38	7.2	<u>0.40</u>	0	0	0	0	No	0	0	No	No	No
2000	7/26/99	1	Yes	150	7.0	0	0	0	0	0	No	0	0	No	No	No
	7/26/99	2	Yes	150	7.0	0.10	0	0	0	0	No	0	20	No	No	No
	8/30/99	3	Yes	95	7.0	0	0	0	0	0	No	0	0	No	No	No
	8/30/99	4	Yes	95	7.0	0	0	0	0	0	No	0	0	No	No	No
2001	7/26/00	1	Yes	5	7.0	0	0	0	0	0	No	0	0	No	No	No
	7/26/00	2	Yes	5	7.0	0	0	0	0	0	No	0	0	No	No	No
	8/30/00	3	Yes	19	7.2	0.20	0	0	0	0	No	0	0	No	No	No
	8/30/00	4	Yes	19	7.2	0	0	0	0	0	No	0	0	No	No	No
<b>01-400-0260</b>																
2001	7/21/00	1	Yes	5	7.8	<u>0.60</u>	0	0	0	0	No	0	0	No	No	No
	7/21/00	2	Yes	5	7.8	<u>0.60</u>	0	0	0	0	No	0	0	No	No	No
<b>01-400-0330</b>																
1999	10/26/98	1	Yes	3	7.7	<u>0.30</u>	0	0	0.10	0	No	25	60	No	No	No
	10/26/98	2	Yes	3	7.3	<u>0.30</u>	0	0	0.10	0	No	0	0	No	No	No
<b>01-400-0485</b>																
2001	2/9/01	1	Yes	DRIPPING	8.0	0	0	0	0	0	No	0	0	No	No	No
	2/9/01	2	Yes	DRIPPING	8.0	0	0	0	<u>1.40</u>	0	No	0	0	No	No	No
	4/5/01	3	Yes	DRIPPING	8.0	0	0	0	0	0.10	No	0	0	No	No	No
	4/5/01	4	Yes	DRIPPING	7.0	0	0	0	0	0.10	No	0	0	No	No	No
<b>01-400-0502</b>																
2001	4/20/01	1	Yes	3	7.0	0	0	0	0	0	No	0	0	No	No	No
	4/20/01	2	Yes	3	7.0	<u>0.80</u>	0	0	0	0	No	0	0	No	No	No
	5/17/01	3	Yes	6	7.5	<u>0.40</u>	0	0	0	0	No	0	0	No	No	No
	5/17/01	4	Yes	6	7.5	<u>0.30</u>	0	0	0	0	No	0	0	No	No	No

Outfall Permit Year	Date	Visit #	Flow ?	Flow Rate (gpm)	pH (su)	Chlorine (ppm)	Copper (ppm)	Phenol (ppm)	Detergents (ppm)	Ammonia (ppm)	Fecal Sample (mpn/100ml)	Turbidity (ntu)	Color	Odor?	Surface Scum	Oil Sheen
<b>01-400-0665</b>																
1999	12/16/98	3	Yes	26	6.0	0	0	0	0	0.60	No	0	0	No	No	No
	12/16/98	4	Yes	26	6.0	0	0	0	0	0.40	No	0	0	No	No	No
2000	7/27/99	1	Yes	10	7.4	0.10	0	0	0	0.20	No	0	30	No	No	No
	7/27/99	2	Yes	10	7.4	0.10	0	0	0	0.20	No	0	60	No	No	No
	8/31/99	3	Yes	0.50	7.8	<u>0.30</u>	0	0	0	0	No	0	25	No	No	No
	8/31/99	4	Yes	0.50	7.8	0.20	0	0	0	0	No	0	20	No	No	No
2001	7/26/00	1	Yes	TLTM	7.8	0	0	0	0	0	No	0	20	No	No	No
	7/26/00	2	Yes	TLTM	7.8	0	0	0	0	0.40	No	0	25	No	No	No
<b>01-400-0770</b>																
2000	2/17/00	1	Yes	1	7.8	0	0	0	0	0.60	No	50	50	No	No	No
	2/17/00	2	Yes	2	7.8	0	0	0	0	0.40	No	25	40	No	No	No
	3/22/00	3	Yes	2	7.8	0	0	0	0	0.40	No	0	30	No	No	No
	3/22/00	4	Yes	2	7.8	0	0	0	0	0.60	No	0	30	No	No	No
2001	7/26/00	1	Yes	0.80	7.8	0.10	0	0	0	0.40	No	0	40	No	No	No
	7/26/00	2	Yes	0.68	7.8	0.20	0	0	0	0.80	No	0	35	No	No	No
	8/30/00	3	Yes	0.95	7.8	0	0	0	0	0.30	No	0	25	No	No	No
	8/30/00	4	Yes	0.95	7.8	0	0	0	0	0.30	No	0	20	No	No	No
<b>01-400-0930</b>																
1999	12/16/98	3	Yes	TOO LOW	7.0	0.10	<u>0.10</u>	0	0	0.60	No	0	0	No	No	No
	12/16/98	4	Yes	TOO LOW	7.0	0	0	0	0	0	No	0	0	No	No	No
2000	7/27/99	1	Yes	2	<u>8.2</u>	0.10	0	0	0	0	No	0	0	No	No	No
	7/27/99	2	Yes	2	<u>8.2</u>	0.10	0	0	0	0	No	0	0	No	No	No
<b>02-100-0090</b>																
1997	2/25/97	1	Yes	2	<u>8.7</u>	0.20	<u>0.10</u>	0	0	0.80	No	50	0	No	No	No
	2/25/97	2	Yes	4	<u>8.5</u>	0	<u>0.20</u>	<u>0.20</u>	<u>0.50</u>	<u>6.00</u>	Yes	35	11	SWEET	No	No
	4/4/97	3	Yes	5	<u>9.2</u>	<u>1.00</u>	0	0	<u>0.25</u>	0	No	10	2	CHLORINE	No	No
	4/4/97	4	Yes	0.90	7.5	0.10	0	0	0	<u>2.00</u>	No	10	4	CHLORINE	No	No
1998	9/16/97	1	Yes	0.16	7.5	0	0	0	<u>0.25</u>	0.40	No	20	20	No	No	No
	9/16/97	2	Yes	0.16	6.7	0	0	0	<u>0.50</u>	<u>6.00</u>	No	20	20	No	No	No
	11/18/97	3	Yes	0.09	<u>8.2</u>	<u>0.30</u>	0	0	<u>0.25</u>	<u>6.00</u>	Yes	0	0	No	No	No
	11/18/97	4	Yes	0.09	<u>8.1</u>	0.20	0	0	0.20	<u>4.00</u>	No	0	0	No	No	No
1999	1/20/99	1	Yes	5	<u>8.1</u>	0.10	0	0	0	0	No	0	0	No	No	No
	1/20/99	2	Yes	5	7.5	0.10	0	0	0	0	No	0	30	No	No	No
	2/22/99	3	Yes	2	7.9	0	0	0	0	0	No	0	0	No	No	No
	2/22/99	4	Yes	2	7.2	0	0	0	0	0	No	0	0	No	No	No

Outfall Permit Year	Date	Visit #	Flow ?	Flow Rate (gpm)	pH (su)	Chlorine (ppm)	Copper (ppm)	Phenol (ppm)	Detergents (ppm)	Ammonia (ppm)	Fecal Sample (mpn/100ml)	Turbidity (ntu)	Color	Odor?	Surface Scum	Oil Sheen
<b>02-100-0103</b>																
1999	1/12/99	1	Yes	2	7.6	0	0	0	0.10	3.00	No	0	30	No	No	No
	1/12/99	2	Yes	2	8.3	0.10	0	0	0.10	1.00	No	0	80	No	No	No
	2/15/99	3	Yes	0.60	7.5	0.10	0	0	0	0	No	0	0	No	No	No
	2/15/99	4	Yes	0.50	8.3	0.30	0	0	0	0.60	No	0	25	No	No	No
2000	7/29/99	1	Yes	0.50	7.7	0	0	0	0	0	No	0	0	No	No	No
	7/29/99	2	Yes	0.50	8.0	0.30	0	0	0.25	0.60	No	0	0	No	No	No
	9/3/99	4	Yes	5	7.0	0.20	0	0	0	0.80	No	0	0	No	No	No
<b>02-100-0105</b>																
1992	11/6/91	1	Yes	4	8.0	0.25	0	0	0		Yes 0	0	0	No	No	No
	11/7/91	2	Yes	4	7.9	0.30	0	0	< 0.25		No	0	0	No	No	No
1997	1/29/97	1	Yes	YES	8.6	0	0	0	0.25	0.40	No	50	20	No	No	No
	1/29/97	2	Yes	YES	8.7	0	0	0	0.25	0.30	No	50	80	No	No	No
	2/24/97	3	Yes	YES	8.4	0	0	0		2.00	No	50	20	No	No	No
	2/25/97	4	Yes	2	9.0	0.10	0.10	0.10		2.00	Yes 15,455	0	0	No	No	No
1998	9/16/97	1	Yes	0.56	6.9	0	0	0	2	1.20	Yes 1,545	50	20	No	No	No
	9/16/97	2	Yes	0.56	7.4	0	0	0	0.25	5.00	No	50	20	DEATH	No	No
	10/13/97	3	Yes	0.60	7.2	0.10	0	0	0.10	1.50	Yes 930,000	15	10	RUST	No	No
	10/13/97	4	Yes	0.56	6.9	0	0	0	0.75	6.00	No	0	0	No	No	No
<b>02-100-0375</b>																
1997	1/17/97	1	Yes	SLIGHT	7.8	0	0	0	0	0	No	50	20	No	No	No
	1/17/97	2	Yes	SLIGHT	8.0	0	0	0	0	0	No	50	20	No	No	No
	2/19/97	3	Yes	SLIGHT	7.7	0	0	0.20	0	0	No	0	0	OIL		Yes
	2/20/97	4	Yes	TRICKLE	8.1	0	0	0	0	0.40	No	0	0	OIL		Yes
<b>02-100-0380</b>																
1997	1/17/97	1	Yes	SLIGHT	8.1	0	0	0	0	0	No	50	20	No	No	No
	1/17/97	2	Yes	SLIGHT	8.2	0	0	0	< 0.25	0	No	50	20	No	No	No
	2/19/97	3	Yes	SLIGHT	8.4	0	0	0	0.25	0	No	0	0	No	No	Yes
	2/19/97	4	Yes	SLIGHT	8.4	0	0	0	0	0	No	0	0	OIL	No	Yes
<b>02-100-0385</b>																
1997	12/3/96	3	Yes	0.40	7.3	0	0	0	0.20	0	No	0	0	No	No	No
	12/4/96	4	Yes	SLIGHT	7.0	0	0	0	0.10	0	No	0	0	No	No	No

Outfall Permit Year	Date	Visit #	Flow ?	Flow Rate (gpm)	pH (su)	Chlorine (ppm)	Copper (ppm)	Phenol (ppm)	Detergents (ppm)	Ammonia (ppm)	Fecal Sample (mpn/100ml)	Turbidity (ntu)	Color	Odor?	Surface Scum	Oil Sheen
<b>02-100-0515</b>																
1992	11/6/91	1	Yes	4	<u>9.0</u>	0.10	<u>0.10</u>	<u>0.10</u>	<u>&lt; 0.25</u>		No	< 25	10	No	No	No
1997	1/7/97	1	Yes	STEADY		0	0	0	<u>0.25</u>	0	No	50	0	No	No	No
	1/7/97	2	Yes	STEADY	7.8	0	0	0	<u>0.25</u>	0	No	50	20	No	No	No
	2/12/97	3	Yes	YES	<u>8.3</u>	0	0	0	<u>0.25</u>	0	No	50	20	No	No	No
	2/12/97	4	Yes	YES	<u>8.2</u>	0	0	0	<u>0.25</u>	0	No	50	20	No	No	No
<b>02-200-0530</b>																
1992	11/6/91	1	Yes	4	<u>8.4</u>	<u>0.60</u>	<u>0.15</u>	0	<u>&lt; 0.25</u>		No	0	10	No	No	No
	11/6/91	2	Yes	4	<u>8.4</u>	<u>0.70</u>	<u>0.10</u>	0	<u>&lt; 0.25</u>		No	0	10	No	No	No
	11/7/91	3	Yes	4	<u>8.4</u>	<u>0.35</u>	<u>0.10</u>	0	<u>&lt; 0.25</u>		No	< 50	10	No	No	No
1997	1/7/97	1	Yes	TRICKLE		<u>2.50</u>	0	0	<u>0.25</u>	0	No	0	0	CHLORINE	No	No
	1/7/97	2	Yes	TRICKLE	<u>8.1</u>	<u>0.60</u>	0	<u>0.20</u>	<u>0.25</u>	0	No	0	15	CHLORINE	No	No
	2/12/97	3	Yes	TRICKLE	<u>8.1</u>	<u>2.50</u>	0	0	<u>1</u>	0.80	No	50	20	CHLORINE	No	No
	2/12/97	4	Yes	TRICKLE	<u>8.6</u>	<u>2.00</u>	0	0	<u>0.25</u>	0	No	50	20	CHLORINE	No	No
1998	9/23/97	1	Yes	0.16	7.2	<u>0.50</u>	0	0	0.10	<u>1.00</u>	Yes	< 1	100	50	No	No
	9/23/97	2	Yes	0.16	7.3	<u>1.00</u>	0	0	0.10	0.10	No	100	50	No	No	No
	11/18/97	3	Yes	0.50	<u>8.2</u>	<u>2.50</u>	0	0	0.10	<u>1.50</u>	Yes	< 1	0	0	No	No
	11/18/97	4	Yes	0.50	<u>8.1</u>	<u>2.00</u>	0	0	0.10	0.10	No	0	0	No	No	No
1999	1/21/99	1	Yes	120	7.5	0	0	0	0	0	No	0	0	No	No	No
	1/21/99	2	Yes	120	7.4	0	0	0	0	0	No	0	0	No	No	No
	2/23/99	3	Yes	120	7.3	0	0	0	0	0	No	0	0	No	No	No
	2/23/99	4	Yes	120	7.6	0	0	0	0	0	No	0	0	No	No	No

Outfall Permit Year	Date	Visit #	Flow ?	Flow Rate (gpm)	pH (su)	Chlorine (ppm)	Copper (ppm)	Phenol (ppm)	Detergents (ppm)	Ammonia (ppm)	Fecal Sample (mpn/100ml)	Turbidity (ntu)	Color	Odor?	Surface Scum	Oil Sheen
<b>02-300-0165</b>																
1992	11/6/91	1	Yes	40	<u>9.0</u>	0	0	0	<u>1.50</u>		No	75	70	No	No	No
	11/7/91	2	Yes	40	7.8	0.10	0	0	<u>0.50</u>		Yes > 600,000	0	15	No	No	No
1997	10/10/96	1	Yes	STEADY	7.2	0	<u>0.15</u>	<u>0.20</u>	<u>0.40</u>		Yes <u>450,000</u>	25	8	SEWAGE		No
	10/11/96	2	Yes	12	7.1	0	0	0	<u>0.35</u>		No	75	40	No	No	No
	11/20/96	3	Yes	20	7.3	0	0	0	<u>&lt; 0.25</u>	<u>2.00</u>	No	15	10	SEWAGE		Yes
1998	11/22/96	4	Yes	10	7.5	0	0	0	0.20	0.40	No	0	0	SEWAGE		Yes
	5/12/98	1	Yes	STEADY	7.3	0	0	0	0	0.40	No	0	0	No	No	No
	5/12/98	2	Yes	STEADY	7.1	0	0	0	0	0.60	No	0	0	No	No	No
	6/26/98	3	Yes	2	7.4	0.10	0	0	0	0.20	Yes <u>2,500</u>	5	25	SEWAGE	No	No
	6/26/98	4	Yes	2	7.0	0.20	0	0	0.15	<u>1.50</u>	No	15	18	SEWAGE	No	No
1999	1/20/99	1	Yes	SLOW	7.7	0	0	0	0.10	0	No	0	0	No	No	No
	1/20/99	2	Yes	SLOW	7.4	0.10	0	0	<u>0.25</u>	0.40	No	0	0	No	No	No
	2/22/99	3	Yes	20	7.6	<u>0.40</u>	0	0	0	0.60	No	0	0	No	No	No
	2/22/99	4	Yes	20	7.7	0.10	0	0	0	0.10	No	0	0	No	No	No
2000	3/23/99	5	Yes	50	<u>8.4</u>	0.05	0	0	<u>0.25</u>	0.35	No	0	0	SEWAGE	POOLING ?	No
	3/23/99	6	Yes	50	<u>8.3</u>	0.10	0	0	<u>0.25</u>	0.40	No	0	0	SEWAGE	POOLING ?	No
	7/30/99	1	Yes	10	7.4	<u>0.30</u>	0	0	<u>0.25</u>	0.60	No	0	0	No	No	No
	7/30/99	2	Yes	10	7.4	0.20	0	0	<u>1.50</u>	<u>2.00</u>	No	0	60	No	No	No
	9/3/99	3	Yes	10	7.0	0.20	0	0	<u>0.50</u>	0	No	0	0	No	No	No
	9/3/99	4	Yes	10	6.0	<u>0.60</u>	0	0	<u>1</u>	<u>2.00</u>	No	0	0	No	No	No
2001	8/4/00	1	Yes	TLTM	7.8	0	0	0	0	0	No	0	30	No	No	No
	8/4/00	2	Yes	TLTM	7.8	<u>0.40</u>	0	0	<u>0.25</u>	<u>1.00</u>	Yes <u>210</u>	0	20	No	No	No
	9/12/00	3	Yes	12	7.8	<u>0.30</u>	0	0	<u>0.50</u>	0.40	No	0	20	No	No	No
	9/12/00	4	Yes	12	7.6	<u>0.30</u>	0	0	<u>0.25</u>	0.20	No	0	20	No	No	No
	6/12/01	5	Yes	SLOW	7.0	<u>0.50</u>	0	0	0	<u>1.50</u>	Yes <u>290,000</u>	0	5	No	No	No
<b>02-300-0180</b>																
1992	3/3/92	1	Yes	4	<u>8.9</u>	<u>1.50</u>	0	0	0		Yes 10	0	0	No	No	No
	3/4/92	2	Yes	4	<u>8.8</u>	<u>1.50</u>	0	0	0		No	0	0	No	No	No
1997	1/29/97	1	Yes	TRICKLE	8.0	<u>2.50</u>	0	0	<u>0.25</u>	0	No	50	20	SULPHUR	No	No
	1/29/97	2	Yes	TRICKLE	<u>8.4</u>	<u>2.50</u>	0	0	<u>0.25</u>	0	No	50	20	No	No	No
<b>02-300-0190</b>																
1992	11/6/91	1	Yes	94	7.7	0	0	0	<u>0.75</u>		No	< 50	25	No	No	No
	11/7/91	2	Yes	157	7.8	< 0.20	0	0	<u>0.25</u>		Yes > 600,000	< 50	20	No	No	No
1997	10/17/96	2	Yes	SLIGHT	7.2	0	<u>0.20</u>	0	<u>1</u>		No	20	0	No	No	No
	11/13/96	3	Yes	SLIGHT	7.4	0	0	0	0	<u>2.00</u>	No	0	75	MUSTY	No	No
	11/15/96	4	Yes	STEADY	7.4	0	0	0	0	<u>1.00</u>	Yes <u>460,000</u>	0	25	No	No	No

Outfall Permit Year	Date	Visit #	Flow ?	Flow Rate (gpm)	pH (su)	Chlorine (ppm)	Copper (ppm)	Phenol (ppm)	Detergents (ppm)	Ammonia (ppm)	Fecal Sample (mpn/100ml)	Turbidity (ntu)	Color	Odor?	Surface Scum	Oil Sheen
<b>02-300-0230</b>																
1992	11/7/91	1	Yes	448	<u>8.2</u>	< 0.10	0	0	<u>&lt; 0.25</u>		No	0	5	No	No	No
	11/8/91	2	Yes	448	7.4	0	0	0	<u>0.65</u>		Yes <u>290</u>	175	70	No	No	No
2000	11/1/99	1	Yes	5	7.4	0	0	0	0	0	No	0	0	No	No	No
	11/1/99	2	Yes	5	7.4	0	0	0	0	0	No	0	0	No	No	No
	12/8/99	3	Yes	150	7.6	0	0	0	0	0	No	0	0	No	No	No
	12/8/99	4	Yes	150	7.4	0	0	0	0	0	No	0	0	No	No	No
<b>02-300-0245</b>																
1997	12/3/96	3	Yes	30	7.9	0	0	0	0.10	0	No	0	0	MUSKY	No	No
	12/4/96	4	Yes	15	<u>8.1</u>	0	0	0	0	0.10	No	0	0	No	No	No
<b>02-300-0270</b>																
1992	11/7/91	1	Yes	4	<u>8.4</u>	< 0.10	0	0	<u>&lt; 0.25</u>		No	< 50	5	No	No	No
	11/8/91	2	Yes	4	7.5	0	0	0	<u>0.65</u>		Yes <u>230</u>	< 50	75	No	No	No
<b>02-300-0295</b>																
1997	1/17/97	1	Yes	STEADY	<u>8.6</u>	0	0	0	0	0	No	50	20	No	No	No
	1/17/97	2	Yes	STEADY	<u>8.4</u>	0	0	0	<u>0.25</u>	0	No	50	20	No	No	No
	2/19/97	3	Yes	STEADY	<u>8.5</u>	0	0	0	<u>0.25</u>	0.10	No	50	0	No	No	No
	2/19/97	4	Yes	SLIGHT	<u>8.5</u>	0	0	0	0	0	No	50	20	No	No	No
2000	12/8/99	4	Yes	TOO LOW	7.6	0	0	0	<u>0.50</u>	0.50	No	50	0	No	No	No
<b>02-400-0045</b>																
1999	10/27/98	1	Yes	2	7.7	<u>2.00</u>	0	0	<u>0.25</u>	0.40	No	0	10	No	No	No
	10/27/98	2	Yes	2	7.7	<u>0.80</u>	0	0	<u>0.50</u>	0.60	No	0	20	No	No	No
	1/12/99	3	Yes	3	8.0	<u>1.00</u>	0	0	<u>0.25</u>	0	No	0	0	No	No	No
	1/12/99	4	Yes	2	8.0	<u>1.00</u>	0	0	<u>0.75</u>	0	No	0	0	No	No	No
2000	7/29/99	1	Yes	0.05	7.7	<u>0.80</u>	0	0	0	0	No	0	0	No	No	No
	7/29/99	2	Yes	0.05	7.8	<u>1.00</u>	0	0	0	0	No	0	0	No	No	No
	9/2/99	3	Yes	0.27	8.0	<u>0.60</u>	0	0	0	0	No	0	0	No	No	No
	9/2/99	4	Yes	0.27	<u>8.2</u>	0.20	0	0	0	0	No	0	0	No	No	No
2001	7/27/00	1	Yes	0.50	7.6	<u>0.80</u>	0	0	<u>0.25</u>	0.20	No	0	0	No	No	No
	7/27/00	2	Yes	0.50	7.8	<u>1.50</u>	<u>0.20</u>	0	0	0.80	No	0	0	No	No	No
	9/8/00	3	Yes	2	<u>8.2</u>	<u>0.60</u>	0	0	0	0	No	0	0	No	No	No
	9/8/00	4	Yes	2	<u>8.2</u>	<u>0.40</u>	0	0	0	0	No	0	0	No	No	No

Outfall Permit Year	Date	Visit #	Flow ?	Flow Rate (gpm)	pH (su)	Chlorine (ppm)	Copper (ppm)	Phenol (ppm)	Detergents (ppm)	Ammonia (ppm)	Fecal Sample (mpn/100ml)	Turbidity (ntu)	Color	Odor?	Surface Scum	Oil Sheen
<b>02-400-0050</b>																
1999	10/27/98	1	Yes	0.20	7.5	<u>3.00</u>	0	0	0	0	No	0	0	No	No	No
	10/27/98	2	Yes	0.20	7.7	<u>2.50</u>	0	0	0	0	No	0	0	No	No	No
2000	1/12/99	3	Yes	0.16	7.7	0	<u>0.80</u>	<u>1.00</u>	0	<u>1.00</u>	Yes 0	0	100	No	No	No
	1/12/99	4	Yes	0.16	7.8	0	<u>1.00</u>	<u>1.00</u>	0	<u>1.00</u>	No	0	100	No	No	No
	7/29/99	1	Yes	0.05	7.7	<u>0.80</u>	0	0	0	0	No	0	0	No	No	No
	7/29/99	2	Yes	0.05	7.8	<u>1.00</u>	0	0	0	0	No	0	0	No	No	No
2001	9/2/99	3	Yes	0.07	7.6	<u>1.50</u>	0	0	0	0	No	0	0	No	No	No
	9/2/99	4	Yes	0.05	7.6	<u>2.00</u>	0	0	0	0	No	0	0	No	No	No
	7/27/00	1	Yes	0.04	7.8	<u>1.00</u>	0	0	0	0	No	0	0	No	No	No
	7/27/00	2	Yes	0.04	<u>8.2</u>	<u>2.00</u>	0	0	0	0	No	0	0	No	No	No
	9/8/00	3	Yes	0.03	<u>8.2</u>	<u>1.50</u>	0	0	0	0	No	0	0	No	No	No
	9/8/00	4	Yes	0.03	<u>8.2</u>	<u>1.50</u>	0	0	0	0	No	0	0	No	No	No
<b>02-400-0055</b>																
1998	1/12/98	1	Yes	2	<u>8.2</u>	0.10	0	0	0	0.10	No	0	0	No	No	No
1999	10/29/98	2	Yes	2	<u>8.2</u>	0	0	0	0	0	No	0	0	No	No	No
	1/12/99	3	Yes	2	<u>8.2</u>	0	0	0	0	0	No	0	0	No	No	No
	1/12/99	4	Yes	2	<u>8.2</u>	0	0	0	0	0	No	0	0	No	No	No
<b>02-400-0060</b>																
1999	1/12/99	3	Yes	0.40	<u>8.1</u>	0	0	0	0	<u>1.00</u>	Yes <u>1,727</u>	0	0	No	No	No
	1/12/99	4	Yes	0.40	8.0	<u>1.00</u>	<u>0.40</u>	0	<u>0.25</u>	<u>1.00</u>	No	50	100	No	No	No
<b>02-400-0070</b>																
1999	1/13/99	3	Yes	3	7.7	0	0	0	0	0	No	0	0	No	No	No
	1/13/99	4	Yes	2	7.8	0	0	0	0	0	No	0	0	No	No	No
<b>02-400-0080</b>																
1999	1/13/99	3	Yes	3	7.7	<u>1.00</u>	0	0	0	0	No	0	0	CHLORINE	No	No
	1/13/99	4	Yes	3	7.7	<u>1.00</u>	0	0	0	0	No	0	0	CHLORINE	No	No
2000	7/30/99	1	Yes	2	7.6	<u>3.00</u>	0	0	0	0	No	0	0	No	No	No
	7/30/99	2	Yes	2	7.6	<u>3.50</u>	0	0	0	0	No	0	0	No	No	No
	9/2/99	3	Yes	10	7.8	<u>3.00</u>	0	0	0	0	No	0	0	No	No	No
	9/2/99	4	Yes	10	7.8	<u>2.50</u>	0	0	0	0	No	0	0	No	No	No

Outfall Permit Year	Date	Visit #	Flow ?	Flow Rate (gpm)	pH (su)	Chlorine (ppm)	Copper (ppm)	Phenol (ppm)	Detergents (ppm)	Ammonia (ppm)	Fecal Sample (mpn/100ml)	Turbidity (ntu)	Color	Odor?	Surface Scum	Oil Sheen
<b>02-400-0169</b>																
1999	1/20/99	1	Yes	19	7.1	0	0	0	0	1.00	Yes	0	0	No	No	No
	1/20/99	2	Yes	2	7.2	0.10	0	0	0	0.20	No	0	0	No	No	No
	2/22/99	3	Yes	10	7.5	0.30	0	0	0	0.10	No	0	30	No	No	No
2000	2/22/99	4	Yes	10	7.4	0.10	0	0	0	0.10	No	0	0	No	No	No
	8/2/99	1	Yes	19	7.0	0.20	0	0	0	0	No	0	0	No	No	No
	8/2/99	2	Yes	0.40	7.4	0.10	0	0	0	0.40	No	0	0	No	No	No
2001	9/3/99	3	Yes	0.27	7.0	0.30	0	0	0	0	No	0	0	No	No	No
	9/3/99	4	Yes	0.27	6.5	0.30	0	0	0	0	No	0	0	No	No	No
2001	8/4/00	1	Yes	0.32	7.8	0	0	0	0	0	No	0	0	No	No	No
	8/4/00	2	Yes	0.63	7.6	0	0	0	0	0.10	No	0	0	No	No	No
<b>02-400-0540</b>																
1999	1/21/99	1	Yes	60	7.5	0	0	0	0	0	No	0	0	No	No	No
	1/21/99	2	Yes	60	7.5	0	0	0	0	0	No	0	0	No	No	No
	2/23/99	3	Yes	108	7.3	0	0	0	0	0	No	0	0	No	No	No
	2/23/99	4	Yes	108	7.3	0	0	0	0	0	No	0	0	No	No	No
<b>03-100-0045</b>																
1997	2/12/97	1	Yes	STEADY		0.30	0	0	0.25	3.00	No	0	0	No	No	No
	2/12/97	2	Yes	HEAVY		2.00	0	0	0.25	0.10	No	0	0	No	No	No
	4/10/97	3	Yes	YES	7.5	0.80	0	0	< 0.25	4.00	Yes	0	2	CHLORINE	No	No
	4/10/97	4	Yes	YES	7.5	2.50	0	0	0	0.10	No	0	3	CHLORINE	No	No
1998	9/22/97	1	Yes	5	7.0	3.00	0	0	0.35	0.40	No	50	20	No	No	No
	9/22/97	2	Yes	5	6.8	3.00	0	0	2	0.20	No	50	20	No	No	No
	12/2/97	3	Yes	0.08	8.5	0	0	0	> 3	10.00	Yes	100	0	YES	No	No
1999	1/21/99	1	Yes	0.24	7.5	0.10	0	0	0	0.10	No	0	0	No	No	No
2000	1/21/99	2	Yes	0.24	8.3	0.10	0	0	0	0.10	No	0	0	No	No	No
	8/2/99	1	Yes	19	8.2	0	0	0	0	0	No	0	0	No	No	No
	8/2/99	2	Yes	1	8.2	1.00	0	0	0	0	No	0	0	No	No	No
2001	9/3/99	3	Yes	2	7.0	1.00	0	0	0	0	No	0	0	No	No	No
	9/3/99	4	Yes	2	7.0	1.00	0	0	0	0	No	0	0	No	No	No
	8/4/00	1	Yes	0.63	8.2	0.30	0	0	0	0.40	No	0	20	No	No	No
	8/4/00	2	Yes	0.95	8.2	0.20	0	0	0.25	1.00	Yes	0	0	No	No	No
	9/12/00	3	Yes	0.50	7.6	0.40	0	0	0	0	No	0	0	No	No	No
2001	9/12/00	4	Yes	0.50	8.2	0.10	0	0	0	0	No	0	0	No	No	No

Outfall Permit Year	Date	Visit #	Flow ?	Flow Rate (gpm)	pH (su)	Chlorine (ppm)	Copper (ppm)	Phenol (ppm)	Detergents (ppm)	Ammonia (ppm)	Fecal Sample (mpn/100ml)	Turbidity (ntu)	Color	Odor?	Surface Scum	Oil Sheen
<b>03-100-0090</b>																
1992	11/12/91	1	Yes	4	<u>8.4</u>	0.15	0	0	<u>0.75</u>		Yes > 6,000	0	0	No	No	No
	11/13/91	2	Yes	4	<u>8.4</u>	0	0	0	<u>0.75</u>		No	0	0	No	No	No
1997	10/9/96	1	Yes	SLIGHT	7.6	0	0.05	0	0.10		Yes 5,800	0	0	No	No	No
	10/10/96	2	Yes	SLIGHT	<u>8.1</u>	0	0	0	0.10	0	No	0	0	No	No	No
	11/20/96	3	Yes	SLIGHT	<u>8.0</u>	0	0	0	0.10	0.35	No	0	5	No	No	No
1998	9/22/97	1	Yes	0.50	7.0	0	0	0	0.20	<u>7.00</u>	Yes 1,400	100	50	No	No	No
	9/23/97	2	Yes	0.50	6.8	0	0	0	0.10	<u>2.00</u>	No	100	50	No	No	No
<b>03-100-0380</b>																
1992	11/13/91	2	Yes	4	<u>8.1</u>	0.15	0	0	<u>&lt; 0.25</u>		Yes 300	< 50	10	No	No	No
1997	10/9/96	1	Yes	SLIGHT		0	0	0	0		Yes 450	0	0	No	No	No
	10/10/96	2	Yes	STEADY	7.4	0	0	0	<u>0.25</u>		No	0	6	No	No	No
	11/20/96	3	Yes	3	7.5	0	0	0	<u>0.25</u>	0	No	0	0	No	No	No
	11/22/96	4	Yes	8	6.9	0	0	0	<u>0.25</u>	0.10	No	0	0	No	No	No
1998	5/13/98	1	Yes	0.50	7.7	0	0	0	<u>0.25</u>	0.30	No	0	35	No	No	No
	5/13/98	2	Yes	0.50	<u>8.1</u>	0	0	0	0	0.30	No	0	20	No	No	No
	6/18/98	3	Yes	0.32	7.7	0	0	0	0	0.30	No	0	0	No	ORANGE	No
	6/18/98	4	Yes	0.48	7.5	0	0	0	0	0.20	No	0	0	No	ORANGE	No
1999	2/3/99	1	Yes	5	7.5	<u>0.30</u>	0	0	0	0.10	No	0	0	No	No	No
	2/3/99	2	Yes	5	7.3	0	0	0	0.10	0.30	No	0	0	No	No	No
2000	9/7/99	3	Yes	0.08	7.5	0	0	0	0	0	No	0	0	No	No	No
	9/7/99	4	Yes	0.08	7.0	0	0	0	0	0	No	0	0	No	No	No
<b>03-200-0870</b>																
1992	11/11/91	1	Yes	4	7.5	0	<u>0.10</u>	0	0		No	75	90	No	No	No
	11/11/91	2	Yes	4	8.0	0	0	0	0		Yes 130	75	40	No	No	No
1997	5/7/97	1	Yes	SLIGHT	7.0	0.15	0	0	<u>&lt; 0.25</u>	0	No	0	0	No	No	No
	5/7/97	2	Yes	YES	7.0	0	0	0	0	0	No	0	0	No	No	No
	6/20/97	3	Yes	MODERA	7.0	0	0	0	0	0	No	0	0	No	No	No
1998	6/20/97	4	Yes	MODERA	7.0	0	0	0	0	0.10	No	0	0	No	No	No
	5/21/98	1	Yes	MODER.	7.3	0	0	0	0	0	No	0	30	No	No	No
	5/21/98	2	Yes	MODER.	7.3	<u>0.40</u>	0	0	0	0	No	0	50	No	No	No
1999	6/18/98	3	Yes	0.79	6.8	0	0	0	0	0.10	No	0	40	No	ORANGE	No
	6/18/98	4	Yes	0.79	6.7	0	0	0	0	0.10	No	0	40	No	No	No
	2/16/99	1	Yes	5	7.6	0	0	0	0	0	No	0	0	No	No	No
	2/16/99	2	Yes	5	7.7	0	0	0	0	0	No	0	0	No	No	No
	3/18/99	3	Yes	10	7.7	0	0	0	0	0	No	0	0	No	No	No
	3/18/99	4	Yes	10	7.8	0	0	0	0	0	No	0	0	No	No	No

Outfall Permit Year	Date	Visit #	Flow ?	Flow Rate (gpm)	pH (su)	Chlorine (ppm)	Copper (ppm)	Phenol (ppm)	Detergents (ppm)	Ammonia (ppm)	Fecal Sample (mpn/100ml)	Turbidity (ntu)	Color	Odor?	Surface Scum	Oil Sheen
<b>03-200-0990</b> 1992	11/12/91	1	Yes	4	7.9	0	0	0	0		No	0	10	No	No	No
	11/12/91	2	Yes	4	7.9	< 0.10	0	0	0		Yes 150	0	10	No	No	No
1997	5/11/97	1	Yes	YES	7.0	0.20	0	0	< 0.25	0	No	50	10	No	No	No
	5/11/97	2	Yes	YES	7.0	0.10	0	0	< 0.25	0.10	No	50	10	No	No	No
	6/20/97	3	Yes	STRONG	7.0	0.30	0	0	< 0.25	0.10	No	25	0	No	No	Yes
1998	6/20/97	4	Yes	STRONG	7.0	0.10	0	0	0	0.20	No	0	0	No	No	Yes
	5/15/98	1	Yes	STEADY	7.8	0	0	0	0	0.10	No	0	0	No	No	No
	5/15/98	2	Yes	STEADY	8.3	0.30	0	0	0	0.10	No	0	0	No	No	No
	6/18/98	3	Yes	1	7.6	0.15	0	0	0	0.10	No	0	30	No	No	No
6/18/98	4	Yes	1	7.6	0.05	0	0	0	0.10	No	0	30	No	No	No	
<b>03-300-0075</b>																
1992	3/3/92	1	Yes	4	7.7	0	0.10	0	0		Yes 10	0	20	No	No	No
	3/4/92	2	Yes	4	7.7	0	0	0	0		No	0	0	No	No	No
1997	5/22/97	1	Yes	0.20	6.5	0	0	0	< 0.25	0.20	No	0	4	No	No	No
	5/22/97	2	Yes	TRICKLE	7.1	0.10	0	0	< 0.25	0.40	No	0	7	No	No	Yes
<b>03-300-0115</b>																
1992	3/3/92	1	Yes	4	6.9	0.15	0.20	0	0.15		Yes 140	25	35	No	No	No
	3/4/92	2	Yes	4	7.9	0	0	0	0		No	0	0	No	No	No
1997	4/8/97	4	Yes	YES	7.0	5.00	0.10	0.10	< 0.25	1.00	No	50	3	No	No	No
<b>03-300-0385</b>																
1997	11/20/96	1	Yes	0.50	7.1	0	0.10	0.10	0.40	0.60	No	25	5	No		No
	11/22/96	2	Yes	5	7.4	0	0	0	0.20	0.10	No	0	0	No		No
	12/4/96	3	Yes	5	7.7	0.10	0.10	0	0.20	0.40	Yes 110	25	40	SLIGHT		Yes
	12/4/96	4	Yes	3	7.7	0.40	0	0.10	0.20	0.10	No	25	30	No		Yes
1998	5/13/98	1	Yes	0.50	7.4	0	0	0	0.20	0.20	No	0	15	No	No	No
	5/13/98	2	Yes	0.50	7.1	0	0	0	0	0.20	No	0	0	No	No	No
	6/18/98	3	Yes	0.16	6.7	0	0	0	0.20	0	No	0	25	No	No	Yes
	6/18/98	4	Yes	0.16	6.8	0.10	0	0	0.20	0	No	50	35	No		Yes
1999	2/5/99	1	Yes	0.12	8.0	0	0	0	0.10	0.40	No	0	70	No	No	No
	2/5/99	2	Yes	0.10	7.6	0	0	0	0.10	0.40	No	0	70	No	No	No
	3/17/99	3	Yes	4	7.9	0.40	0	0	0	0.10	No	0	0	No	SOME FOA	No
2000	3/17/99	4	Yes	0.11	7.7	0	0	0	0	0.40	No	25	40	SOUR		Yes
	8/2/99	1	Yes	10	7.6	0	0	0	0	0.40	No	0	0	No	No	No
	8/2/99	2	Yes	10	7.6	0	0	0	0	0.20	No	0	0	No	No	No

Outfall Permit Year	Date	Visit #	Flow ?	Flow Rate (gpm)	pH (su)	Chlorine (ppm)	Copper (ppm)	Phenol (ppm)	Detergents (ppm)	Ammonia (ppm)	Fecal Sample (mpn/100ml)	Turbidity (ntu)	Color	Odor?	Surface Scum	Oil Sheen	
<b>03-300-0400</b> 1999	5/20/99	1	Yes	1	7.0	0.10	0	0	0	0.30	No	0	50	No	No	No	
	5/20/99	2	Yes	1	6.5	0.10	0	0	0	0.60	No	0	10	No	No	No	
	6/18/99	3	Yes	0.06	7.5	<u>0.30</u>	0	0	0	0.40	No		0	No	No	No	
2001	12/26/00	3	Yes	1	6.8	0	0	0	0	0	No	0	0	No	No	No	
	12/26/00	4	Yes	1	6.8	0	0	0	0	0	No	0	0	No	No	No	
<b>03-300-0615</b> 1997	1/29/97	1	Yes	HEAVY	6.5	0.10	<u>0.10</u>	0	<u>0.25</u>	0.10	No	0	0	CHEMICAL	No	No	
	1/29/97	2	Yes	YES	6.6	0	<u>0.10</u>	0	<u>0.25</u>	0.10	No	0	0	CHEMICAL	No	Yes	
	3/12/97	3	Yes	STEADY	7.9	<u>0.40</u>	0	<u>0.20</u>	0.10	0.40	No	20	6	PETRO.		Yes	
	3/12/97	4	Yes	16	7.9	0	0	0	0.15	0.80	No	15	6	PETRO.	No	No	
<b>03-300-0640</b> 2000	12/28/99	3	Yes	150	7.4	0	0	0	0	0	No	0	0	No	No	No	
	12/28/99	4	Yes	150	7.4	0	0	0	0	0	No	0	0	No	No	No	
<b>03-300-0655</b> 1992	3/4/92	1	Yes	4	<u>8.1</u>	0	0	<u>0.10</u>	0		No	0	35	No	No	No	
	3/4/92	2	Yes	4							Yes	0		No	No	No	
	1997	1/29/97	1	Yes	YES	6.6	0.10	0	0	<u>0.25</u>	0	No	0	0	No		No
		1/29/97	2	Yes	YES	6.9	0.10	0	0	<u>0.25</u>	0	No	0	0	No		No
		3/12/97	3	Yes	16	<u>8.4</u>	0.15	0	0	0.15	<u>1.50</u>	Yes	10	35	8	No	No
		3/13/97	4	Yes	16		0	0	0	0.15	<u>9.00</u>	No		0	0	No	No
	1998	10/2/97	1	Yes	5	6.5	0	0	0	<u>1.50</u>	0.10	No	50	20	No	GREEN	No
		10/2/97	2	Yes	7	<u>5.7</u>	0	0	0	<u>0.75</u>	0.10	No	50	50	GASOLINE	SUDS	No
		12/2/97	3	Yes	5	<u>8.1</u>	0	0	0	0.20	0	No	50	0	No	No	No
		12/2/97	4	Yes	5	<u>8.2</u>	0	0	0	0.10	0	No	50	0	No	No	No
1999	3/17/99	3	Yes	2	8.0	0	0	0	0	0.10	No	50	45	No	No	No	
	3/17/99	4	Yes	2	8.0	0	0	0	0	0.10	No	0	0	No	No	No	

Outfall Permit Year	Date	Visit #	Flow ?	Flow Rate (gpm)	pH (su)	Chlorine (ppm)	Copper (ppm)	Phenol (ppm)	Detergents (ppm)	Ammonia (ppm)	Fecal Sample (mpn/100ml)	Turbidity (ntu)	Color	Odor?	Surface Scum	Oil Sheen
<b>03-300-0660</b> 1997	10/9/96	1	Yes	SLIGHT		0	0	0	0.10		Yes 164	0	0	No	No	No
	10/10/96	2	Yes	STEADY	7.5	0	0.10	0.10	0.25		No	50	10	No	No	No
	11/13/96	3	Yes	FAST	7.6	0	0.10	0	0	0.10	No	50	20	No	No	No
	11/15/96	4	Yes	FAST	7.3	0	0.10	0	0	0.10	No	25	10	No	No	No
2000	11/23/99	1	Yes	TOO LOW	7.8	0	0	0	0.50	0	No	0	0	No	No	No
	11/23/99	2	Yes	TOO LOW	7.8	0	0	0	0.50	0	No	0	0	No	No	No
	12/28/99	3	Yes	0.80	7.6	0	0	0	0	0	No	0	0	No	No	No
	12/28/99	4	Yes	0.80	7.4	0	0	0	0	0	No	0	0	No	No	No
2001	8/8/00	1	Yes	0.99	7.8	0.60	0	0	0	0	No	0	0	No	No	No
	8/8/00	2	Yes	0.99	7.8	0.20	0	0	0	0	No	0	0	No	No	No
	9/27/00	3	Yes	19	7.8	0	0	0	0	0	No	0	20	No	No	No
	9/27/00	4	Yes	10	7.8	0.20	0	0	0	0	No	0	0	No	No	No
<b>03-300-0670</b> 1992	3/4/92	1	Yes	4	7.4	0	0	0.10	0		No	25	55	No	No	No
	3/4/92	2	Yes	4	7.5	0.15	0	0	0		No	0	0	No	No	No
1997	1/29/97	1	Yes	STEADY	6.3	0	0	0	0.25	0.10	No	0	0	GASOLINE		No
	1/29/97	2	Yes	YES	6.6	0	0	0	0.25	0.10	No	0	0	CHEMICAL		No
	3/12/97	3	Yes	2	8.0	0.10	0	0	0.10	1.50	Yes < 1	15	7			No
	3/12/97	4	Yes	2		0	0	0	0.10	0.50	No	0	0			No
<b>03-400-0570</b> 2000	4/6/00	3	Yes	12	7.2	0	0	0	0	0	No	0	0	No	No	No
	4/6/00	4	Yes	12	7.2	0	0	0	0	0	No	0	0	No	No	No
<b>03-400-0665</b> 2000	10/18/99	3	Yes	TOO LOW	8.0	0.60	0	0	0	0	No	25	50	No	No	No
	10/18/99	4	Yes	TOO LOW	8.0	0.30	0	0.20	0	0.60	No	20	45	No	No	No
2001	9/27/00	3	Yes	0.20	7.6	0	0	0	0	0	No	0	0	No	No	No
	9/27/00	4	Yes	16	7.6	0	0	0	0	0	No	0	0	No	No	No
<b>03-500-0540</b> 2000	3/2/00	1	Yes	100	7.8	0	0	0	0	0	No	0	0	No	No	No
	3/2/00	2	Yes	100	7.4	0	0	0	0	0	No	0	0	No	No	No
	4/6/00	3	Yes	300	7.4	0	0	0	0	0	No	0	0	No	BROWN	No
	4/6/00	4	Yes	300	7.4	0	0	0	0	0	No	0	0	No	No	No

Outfall Permit Year	Date	Visit #	Flow ?	Flow Rate (gpm)	pH (su)	Chlorine (ppm)	Copper (ppm)	Phenol (ppm)	Detergents (ppm)	Ammonia (ppm)	Fecal Sample (mpn/100ml)	Turbidity (ntu)	Color	Odor?	Surface Scum	Oil Sheen
<b>04-100-0250</b>																
1992	11/14/91	1	Yes	4	<u>8.2</u>	0	0	0	<u>&lt; 0.25</u>		No	0	0	No	No	No
	11/15/91	2	Yes	4	7.9	< 0.10	0	0	<u>&gt; 3</u>		Yes <u>1,400</u>	50	100	No	No	No
<b>04-200-0270</b>																
1992	11/13/91	1	Yes	403	<u>8.1</u>	0.10	0	0	< 0.10		No	0	8	No	No	No
	11/14/91	2	Yes	345	<u>8.1</u>	0	0	0	<u>&lt; 0.25</u>		Yes <u>200</u>	0	0	No	No	No
1997	10/31/96	1	Yes	30	7.4	0	0	0	0.10		Yes 155	0	0	No	No	No
	11/1/96	2	Yes	10	7.3	0	0	0	0.20	0	No	5	15	No	No	No
	12/3/96	3	Yes	HEAVY	7.5	0	0	0	0.10	0	No	0	0	No	No	No
	12/3/96	4	Yes	10	7.2	0	0	0	<u>0.25</u>	0	No	0	0	No	No	No
<b>04-400-0210</b>																
2000	3/29/00	3	Yes	0.18	7.4	0.10	0	0	0	0.20	No	0	0	No	No	No
	3/29/00	4	Yes	0.12	7.4	0	0	0	0	0.20	No	0	0	No	No	No
<b>04-400-0300</b>																
2000	2/29/00	1	Yes	5	7.8	<u>2.00</u>	0	0	0	0	No	0	20	No	No	No
	2/29/00	2	Yes	5	7.8	<u>1.00</u>	0	0	0	0	No	0	15	No	No	No
	3/29/00	3	Yes	3	7.8	<u>1.50</u>	0	0	0	0	No	0	0	No	No	No
	3/29/00	4	Yes	3	7.8	<u>1.50</u>	0	0	0	0	No	0	0	No	No	No
2001	8/8/00	1	Yes	5	7.6	<u>1.50</u>	0	0	0	0	No	0	0	No	No	No
	8/8/00	2	Yes	5	<u>8.2</u>	0.25	0	0	<u>0.25</u>	<u>3.00</u>	Yes <u>2,376</u>	0	60	No	No	No
	9/27/00	3	Yes	4	<u>8.2</u>	<u>2.00</u>	0	0	0	0	No	0	0	No	No	No
	9/27/00	4	Yes	5	<u>8.2</u>	<u>1.50</u>	0	0	0	0	No	0	0	No	No	No
<b>04-400-0335</b>																
1998	11/24/97	1	Yes	MODER.	7.5	0	0	0	0	0	No	0	0	No	No	No
	11/24/97	2	Yes	MODER.	7.5	0	0	0	0	0.10	No	0	0	No	No	No
	1/29/98	3	Yes	YES	6.6	0	0	0	0	0	No	0	0	No	No	No
	1/29/98	4	Yes	YES	7.3	0	0	0	0	0	No	0	0	No	No	No
<b>04-500-0238</b>																
2001	4/16/01	1	Yes	UNMEASL	8.0	<u>0.60</u>	<u>0.25</u>	<u>0.10</u>	<u>1.50</u>	0.20	No	0	0	No	No	No
	4/16/01	2	Yes	UNMEASL	8.0	<u>0.70</u>	<u>0.20</u>	0	0.10	0.20	No	0	0	No	No	No
	5/16/01	3	Yes	VERY LIG	8.0	<u>1.50</u>	0	0	0	0.80	No	50	0	No	No	No

Outfall Permit Year	Date	Visit #	Flow ?	Flow Rate (gpm)	pH (su)	Chlorine (ppm)	Copper (ppm)	Phenol (ppm)	Detergents (ppm)	Ammonia (ppm)	Fecal Sample (mpn/100ml)	Turbidity (ntu)	Color	Odor?	Surface Scum	Oil Sheen
<b>05-100-0165</b>																
1997	2/12/97	1	Yes	0.10	7.7	0	0	0	0	0	No	0	0	No	No	No
	2/12/97	2	Yes	0.10	7.4	0	0	0	0	0	No	0	0	No	No	No
	3/17/97	3	Yes	1	7.2	0	0	0	0	0	No	0	0	No	No	No
	3/17/97	4	Yes	1	6.9	0	0	0	0.10	0.50	No	0	0	No	No	No
1998	10/6/97	1	Yes	3	6.9	0.05	0	0	0.10	0	No	20	20	No	No	No
	10/6/97	2	Yes	3	6.8	0.08	0	0	0.10	0	No	20	20	No	No	No
	12/17/97	3	Yes	1	7.8	0	0	0	0.10	0	No	0	0	No	No	No
	12/18/97	4	Yes	1	8.0	0	0	0	0.10	0	No	50	40	No	No	No
<b>05-100-0200</b>																
1997	2/18/97	1	Yes	SLIGHT	<u>8.1</u>	0	0	0	<u>&lt; 0.25</u>	0	No	0	0	No	No	No
	2/18/97	2	Yes	SLIGHT	<u>8.2</u>	0	0	0	<u>&lt; 0.25</u>	0	No	0	0	No	No	No
	4/4/97	3	Yes	TRICKLE	7.4	0	0	0	0	0	No	0	0	No	No	No
	4/4/97	4	Yes	TRICKLE	7.5	0	0	0	0	0	No	0	0	No	No	No
<b>05-300-0035</b>																
1997	2/12/97	1	Yes	2	7.5	0	0	0	0.15	0.10	No	0	0	No	No	No
	2/12/97	2	Yes	2	7.5	0	0	0	0.10	0	No	0	0	No	No	No
	3/17/97	3	Yes	2	7.1	0	0	0	0.10	0	No	0	0	No	No	No
	3/17/97	4	Yes	2	6.9	0	0	0	0.10	<u>1.10</u>	No	0	0	No	No	No
1998	12/17/97	3	Yes	5	7.9	0	0	0	0.10	0.10	No	0	0	No	GREEN	No
	12/18/97	4	Yes	5	7.6	0	0	0	0.10	0	No	0	0	No	GREEN	No
<b>05-300-0210</b>																
2000	12/29/99	1	Yes	63	6.8	<u>0.40</u>	0	0	0	0	No	0	0	No	No	No
	12/29/99	2	Yes	63	7.0	<u>0.40</u>	0	0	0	0	No	0	0	No	No	No
	2/2/00	3	Yes	100	8.0	<u>0.40</u>	0	0	0	0	No	0	0	No	No	No
	2/2/00	4	Yes	100	7.8	0	0	0	0	0	No	0	0	No	No	No
2001	8/14/00	1	Yes	300	7.8	<u>0.30</u>	0	0	0	0	No	0	20	No	No	No
	8/14/00	2	Yes	300	7.8	0.20	0	0	0	0	No	0	10	No	No	No
	9/29/00	3	Yes	10	7.0	0	0	0	0	0	No	0	0	No	No	No
	9/29/00	4	Yes	10	7.8	0	0	0	0	0	No	0	0	No	No	No
<b>05-300-0240</b>																
1997	2/18/97	1	Yes	SLIGHT	<u>8.1</u>	0	0	0	0	0.30	No	50	20	No		Yes
	2/18/97	2	Yes	SLIGHT	7.9	0	0	0	<u>&lt; 0.25</u>	0.20	No	50	20	No	No	No

Outfall Permit Year	Date	Visit #	Flow ?	Flow Rate (gpm)	pH (su)	Chlorine (ppm)	Copper (ppm)	Phenol (ppm)	Detergents (ppm)	Ammonia (ppm)	Fecal Sample (mpn/100ml)	Turbidity (ntu)	Color	Odor?	Surface Scum	Oil Sheen
<b>05-400-0045</b>																
1998	1/29/98	1	Yes	1	7.0	<u>2.10</u>	0	0	0	0	No	0	0	CHLORINE	No	No
	1/29/98	2	Yes	1	7.0	<u>2.00</u>	0	0	0	0	No	0	0	CHLORINE	No	No
	4/13/98	3	Yes	2	7.0	<u>3.00</u>	0	0	<u>0.25</u>	0	No	0	0	CHLORINE	No	No
	4/13/98	4	Yes	0.60	7.0	<u>4.00</u>	0	0	<u>0.25</u>	0	No	0	0	CHLORINE	No	No
1999	3/5/99	1	Yes	0.03	7.8	0	<u>0.20</u>	0	<u>0.25</u>	<u>2.00</u>	Yes 54	50	70	No	No	No
	3/5/99	2	Yes	0.03	<u>8.2</u>	0.10	<u>0.20</u>	0	0.10	<u>2.00</u>	No	50	90	No	No	No
	4/5/99	3	Yes	0.01	<u>8.2</u>	0.10	<u>0.10</u>	<u>0.10</u>	<u>0.50</u>	<u>4.00</u>	Yes <u>12,090</u>	0	40	No	No	No
	4/5/99	4	Yes	0.01	7.5	0.10	0	0	<u>0.25</u>	<u>1.00</u>	No	0	40	No	No	No
<b>05-400-0245</b>																
1998	1/29/98	1	Yes	SLOW	7.0	0	0	0	0	0.10	No	0	45	No	No	No
	1/29/98	2	Yes	SLOW	7.0	0	0	0	0	0.10	No	0	30	No	No	Yes
<b>05-500-0015</b>																
1998	5/6/98	1	Yes	5	<u>8.4</u>	0	0	0	0	0.20	No	20	0	No	SLIGHT	No
	5/6/98	2	Yes	5	<u>8.1</u>	0	0	0	0	0	No	20	0	No	SLIGHT	No
<b>06-100-0200</b>																
1992	11/19/91	1	Yes	4	<u>5.6</u>	0.10	<u>0.20</u>	<u>0.30</u>	<u>3</u>		Yes <u>&gt; 6,000</u>	250	35	No	No	No
	11/20/91	2	Yes	4	<u>4.4</u>	<u>0.30</u>	<u>0.20</u>	<u>0.20</u>	<u>3</u>		No	250	35	No	No	No
1997	12/3/96	3	Yes	0.80	8.0	0	0	0	0.10	0.10	No	0	0	MUSKY	No	No
	12/4/96	4	Yes	0.80	<u>8.2</u>	0	0	0	0.10	0.10	No	0	0	MUSKY	No	No
<b>06-200-0155</b>																
1997	2/19/97	1	Yes	3	8.0	0	0	0	0.10	0.40	No	0	0	No		No
	2/20/97	2	Yes	3	<u>8.3</u>	0.05	0	0	0.10	0.10	No	0	0	No	No	No
	3/27/97	3	Yes	3	7.4	0	0	0	<u>0.30</u>	0	No	0	0	No	No	No
	3/27/97	4	Yes	3	7.8	0	0	0	0.10	0	No	0	0	No		No
<b>06-400-0145</b>																
1999	3/12/99	1	Yes	20	7.8	0.10	0	0	0	0.60	No	0	0	No	No	No
	3/12/99	2	Yes	20	7.5	<u>0.30</u>	0	0	0	0.10	No	0	0	No	No	No
	4/12/99	3	Yes	0.26	6.5	0.10	0	0	0	0	No	25	0	No	No	No
	4/12/99	4	Yes	0.31	6.5	0.10	0	0	0	0	No	0	0	No	No	No
<b>06-400-0170</b>																
1998	1/29/98	1	Yes	0.60		0	0	0	0	0	No	0	0	No	ALGAE	No
	1/29/98	2	Yes	0.60	7.0	0	0	0	0	0.10	No	0	0	No	ALGAE	No

Outfall Permit Year	Date	Visit #	Flow ?	Flow Rate (gpm)	pH (su)	Chlorine (ppm)	Copper (ppm)	Phenol (ppm)	Detergents (ppm)	Ammonia (ppm)	Fecal Sample (mpn/100ml)	Turbidity (ntu)	Color	Odor?	Surface Scum	Oil Sheen
<b>06-500-0110</b> 1992	11/19/91	1	Yes	40	7.9	< 0.10	0	0	0		Yes 10	0	0	No	No	No
	11/20/91	2	Yes	40	7.7	0	0	0	< 0.25		No	0	0	No	No	No
<b>07-100-0055</b> 1992 1997 1998 1999 2000 2001	11/20/91	1	Yes	27	7.5	0.15	0	0	0.25		Yes 6,000	0	0	No	No	No
	11/20/91	2	Yes	27	7.6	0.15	0	0	0.75		No	0	0	FISH	No	No
	5/7/97	1	Yes	HEAVY	7.0	0.10	0	0	0	0.80	Yes 9,091	0	0	No	No	No
	5/7/97	2	Yes	YES	7.0	0	0	0	0	0	No	0	0	No	No	No
	6/20/97	3	Yes	2	7.0	0	0	0	0.10	0.20	No	5	0	No	No	No
	6/20/97	4	Yes	2	6.2	0	0	0	0	0	No	5	5	No	No	No
	5/13/98	1	Yes	2	7.5	0	0	0	0.20	0.30	No	0	10	No	No	No
	5/13/98	2	Yes	2	8.3	0	0	0	0.25	0.20	No	0	15	No	No	No
	6/24/98	3	Yes	5	7.0	0	0	0	0	0.20	No	0	0	No	No	No
	6/24/98	4	Yes	3	7.3	0	0	0	0	0.60	No	0	0	No	No	No
	3/17/99	1	Yes	150	8.2	0.10	0	0	0	0.40	No	0	0	No	No	No
	3/17/99	2	Yes	150	8.1	0	0	0	0.25	0.40	No	0	0	No	No	No
	4/19/99	3	Yes	60	6.0	0	0	0	0	0	No	0	0	No	No	No
	4/19/99	4	Yes	60	6.0	0	0	0	0.25	0	No	0	0	No	No	No
	8/17/99	1	Yes	5	7.6	0	0	0	0	0.30	No	0	0	No	No	No
8/18/99	2	Yes	5	7.6	0	0	0	0.25	0.60	No	0	0	No	No	No	
9/13/99	3	Yes	0.50	7.0	0	0	0	0	0.20	No	0	0	No	No	No	
9/13/99	4	Yes	0.50	6.5	0	0	0	0	0	No	0	0	No	No	No	
8/14/00	1	Yes	200	7.8	0	0	0	0	0	No	0	0	No	No	No	
8/14/00	2	Yes	200	7.8	0	0	0	0	0	No	0	0	No	No	No	
10/3/00	3	Yes	19	8.0	0	0	0	0	0	No	0	0	No	No	No	
10/4/00	4	Yes	19	7.0	0	0	0	0	0	No	0	0	No	No	No	
<b>07-100-0090</b> 1997 1998 1999	10/31/96	1	Yes	2	8.1	0	0	0	0.25		Yes 600,000	10	10	LAUNDRY		No
	11/1/96	2	Yes	3	8.0	0	0	0	0.25		No	0	10	No		No
	12/3/96	3	Yes	FAST	8.0	0	0	0	0.25	1.50	Yes 90,000	0	0	No	No	No
	12/3/96	4	Yes	STEADY	7.7	0	0	0	0.10	0.25	No	0	0	No	No	No
	10/6/97	1	Yes	10	7.2	0	0	0	0.25	3.50	Yes 1,360,000	50	50	FECAL		Yes
	10/6/97	2	Yes	10	7.0	0	0	0	1	9.00	No	50	20	FECAL		Yes
	12/17/97	3	Yes	10	8.2	0	0	0	0.25	3.50	Yes 680,000	0	0	FECAL		No
	12/18/97	4	Yes	10	8.2	0	0	0	0.30	3.00	No	50	20	SEWAGE	BROWN	No
	3/17/99	1	Yes	60	8.2	0	0	0	0.25	0.30	No	0	15	No	No	No
	3/17/99	2	Yes	60	7.6	0	0	0	0.25	0.20	No	0	0	No	No	No
4/19/99	4	Yes	TOO LOW	6.0	0.20	0	0	0	2	0.40	No	0	0	No	No	No

Outfall Permit Year	Date	Visit #	Flow ?	Flow Rate (gpm)	pH (su)	Chlorine (ppm)	Copper (ppm)	Phenol (ppm)	Detergents (ppm)	Ammonia (ppm)	Fecal Sample (mpn/100ml)	Turbidity (ntu)	Color	Odor?	Surface Scum	Oil Sheen
<b>07-100-0205</b> 1997	2/17/97	1	Yes	0.50	7.6	0	0	0	0.10	0.30	No	10	10	SEWER	No	No
	2/18/97	2	Yes	0.25	7.8	0.20	<u>0.10</u>	0	0	0.30	Yes 55	10	10	No	No	No
	3/27/97	3	Yes	2	7.5	0.10	0	0	<u>0.25</u>	0	No	0	20	No	No	No
	3/27/97	4	Yes	2	7.8	0.10	0	0	0.10	0	No	0	20	No		No
<b>07-200-0015</b> 1997	10/31/96	1	Yes	0.50	7.8	0	0	0	0.10		Yes 100	0	0	No	No	No
	11/1/96	2	Yes	0.50	7.5	0	0	0	0.20		No	0	10	No	No	No
	12/3/96	3	Yes	SLIGHT	<u>8.3</u>	0	0	0	0.10	0	No	0	0	No		No
	12/3/96	4	Yes	SLIGHT	<u>8.2</u>	0	0	0	0.15	0.10	No	0	0	No		No
<b>07-400-0045</b> 1999	3/17/99	1	Yes	6	7.5	0.10	0	0	<u>0.25</u>	0.10	No	0	40	No	No	No
	3/17/99	2	Yes	6	7.8	0.20	0	0	<u>0.25</u>	0.20	No	0	40	No	No	No
	4/19/99	3	Yes	0.29	6.0	0.10	0	0	<u>0.25</u>	0	No	0	40	No	No	No
	4/19/99	4	Yes	0.29	6.5	0	0	0	<u>2</u>	0	No	0	30	No	No	No
<b>07-400-0070</b> 2001	12/11/00	1	Yes	0.00	<u>0.0</u>	0	0	0	0	0	No	0	0	No	No	No
	12/11/00	2	Yes	TLTM	7.5	0	0	<u>0.50</u>	<u>3</u>	<u>10.00</u>	Yes	30		SEWAGE	No	No
	1/11/01	3	Yes	5	7.5	0	0	<u>0.20</u>	<u>3</u>	<u>10.00</u>	Yes <u>1,180,000</u>	50	30	SEWAGE	No	No
	1/11/01	4	Yes	5	7.5	0	0	<u>0.40</u>	<u>3</u>	<u>10.00</u>	No	50	30	SEWAGE	No	No
	6/12/01	5	Yes	SLOW	7.5	<u>0.90</u>	0	0	<u>1</u>	<u>10.00</u>	No	50	45	No	No	No
<b>10-200-0040</b> 1997	3/21/97	3	Yes	1	7.1	0.20	0	0	0.10	<u>1.50</u>	Yes 5	0	20	No	No	No
	3/21/97	4	Yes	0.00	7.1	0	0	0	0.10	<u>5.00</u>	No	0	0	No	No	No
<b>10-500-0025</b> 2001	1/3/01	1	Yes	3	7.5	0.20	0	0	0	0.10	No	0	0	No	No	No
	1/3/01	2	Yes	3	7.5	<u>2.00</u>	0	0		0.25	No	0	0	No	No	No
	2/5/01	3	Yes	HEAVY	7.0	0	0	0	0	0	No	0	0	No	No	No
	2/5/01	4	Yes	HEAVY	7.5	0	0	0	0	0	No	0	0	No	No	No
<b>10-500-0035</b> 2001	12/1/00	3	Yes	0.08	8.0	<u>0.70</u>	0	0	0	0.70	No	0	0	No	No	No
	12/1/00	4	Yes	0.08	8.0	0	<u>0.10</u>	0	<u>0.25</u>	0.70	No	0	0	No	No	No
	2/5/01	6	Yes	DRIPPING	7.0	0	0	0	<u>3</u>	0	No	0	0	No	No	No
	2/5/01	7	Yes	DRIPPING	7.0	0	0	0	<u>3</u>	0	No	0	0	No	No	No

Outfall Permit Year	Date	Visit #	Flow ?	Flow Rate (gpm)	pH (su)	Chlorine (ppm)	Copper (ppm)	Phenol (ppm)	Detergents (ppm)	Ammonia (ppm)	Fecal Sample (mpn/100ml)	Turbidity (ntu)	Color	Odor?	Surface Scum	Oil Sheen	
<b>11-200-0595</b> 1997	2/19/97	1	Yes	1	7.2	0	0	0	0.10	0	No	0	0	No		Yes	
	2/20/97	2	Yes	0.50	7.6	0	0	0	0.10	0.30	No	0	0	No		Yes	
	3/24/97	3	Yes	1	7.6	0	0	0	0.10	0	No	0	0	No		No	
	3/25/97	4	Yes	1	6.8	0.10	0	0	0.10	0	No	0	20	No		No	
<b>11-400-0585</b> 1998	5/20/98	1	Yes	0.50	<u>8.9</u>	0	0	0	<u>0.25</u>	0.40	Yes <u>310</u>	0	0	No	No	Yes	
	5/20/98	2	Yes	0.50	<u>8.7</u>	0	0	0	<u>0.25</u>	0.40	No	0	0	No	No	Yes	
	6/18/98	3	Yes	0.50	<u>8.3</u>	0	0	0	0.20	0.30	No	0	0	No	No	Yes	
	6/18/98	4	Yes	0.50	<u>8.5</u>	0	0	0	0.20	0.40	No	0	0	No	No	Yes	
1999	3/19/99	1	Yes	5	7.5	0.10	0	0	0.10	0.10	No	0	0	No	No	No	
	3/19/99	2	Yes	5	7.8	0	0	0	0	0	No	0	0	No	No	No	
	5/3/99	3	Yes	1	6.5	0	0	0	0	0	No	0	0	No	No	No	
	5/3/99	4	Yes	2	6.5	0	0	0	<u>0.25</u>	0.10	No	0	35	No	No	No	
<b>11-400-0590</b> 1997	2/20/97	1	Yes	2	7.6	0	0	0	<u>1</u>	<u>1.00</u>	Yes <u>410</u>	0	0	No	No	No	
	2/21/97	2	Yes	2	7.2	0	0	0	<u>0.40</u>	<u>1.00</u>	No	0	0	No	No	No	
	3/24/97	3	Yes	1	7.2	0	0	0	0.10	<u>3.50</u>	No	0	20	No	No	No	
	3/25/97	4	Yes	1	6.8	<u>0.30</u>	0	0	<u>&gt; 3</u>	<u>&gt; 10.00</u>	No	20	20	ROTTEN	No	No	
	1998	1/5/98	1	Yes	10	<u>8.2</u>	0	0	0	0.10	<u>3.00</u>	No	100	100	No	No	No
		1/5/98	2	Yes	10	<u>8.3</u>	0	0	0	0.10	<u>2.00</u>	No	100	100	No	No	No
		3/11/98	3	Yes	8	<u>8.4</u>	0	0	0	0.10	<u>2.00</u>	No	50	100	No	No	No
		3/11/98	4	Yes	8	<u>8.5</u>	0	0	0	0.10	<u>2.00</u>	No	50	70	No	No	No
	1999	3/19/99	1	Yes	5	7.4	0	0	0	0	0.10	No	0	0	No	No	No
		5/3/99	2	Yes	2	7.0	0	0	0	<u>0.25</u>	0.15	No	0	0	No	WHITE & D	No
5/3/99		3	Yes	2	7.0	0	0	0	<u>0.25</u>	0.15	No	0	0	No	WHITE & D	No	
	5/3/99	4	Yes	2	6.0	0	0	0	0	0.10	No	0	0	No	WHITE & D	No	
<b>12-200-0055</b> 1992	11/14/91	1	Yes	85	<u>8.5</u>	< 0.10	0	0	0		Yes 20	0	0	No	No	No	
	11/15/91	2	Yes	85	<u>8.3</u>	0	0	0	0		No	0	0	No	No	No	
<b>12-400-0005</b> 1997	5/7/97	1	Yes	YES	6.7	0	0	0	0.10	0.10	No	0	0	No	No	No	
	5/7/97	2	Yes	YES	7.1	0	0	0	0.10	0	No	0	0	No	No	No	
	6/24/97	3	Yes	5	7.0	0	0	0	0.10	0.10	No	0	0	No	No	No	
	6/24/97	4	Yes	5	7.1	0	0	0	0.10	0	No	0	0	No	No	No	

Outfall Permit Year	Date	Visit #	Flow ?	Flow Rate (gpm)	pH (su)	Chlorine (ppm)	Copper (ppm)	Phenol (ppm)	Detergents (ppm)	Ammonia (ppm)	Fecal Sample (mpn/100ml)	Turbidity (ntu)	Color	Odor?	Surface Scum	Oil Sheen
<b>12-400-0045</b>																
1998	5/21/98	1	Yes	MODERA	6.5	<u>1.50</u>	0	0	0	0	No	0	10	No	No	No
	5/21/98	2	Yes	MODERA	<u>9.2</u>	0.10	0	0	0	0.30	No	10	25	No	FILMY	No
<b>13-100-0240</b>																
1992	11/12/91	1	Yes	4	8.0	0	0	0	0		No	200	450	No	No	No
	11/13/91	2	Yes	4	7.8	0	0	0	<u>0.35</u>		Yes <u>330</u>	0	5	No	No	No
1997	11/4/96	1	Yes	TRICKLE	<u>8.3</u>	0	0	0	0.10		Yes <u>11,000</u>	0	20	No	No	No
	11/5/96	2	Yes	TRICKLE	<u>8.2</u>	0	0	0	0.10		No	0	15	No	No	No
	12/5/96	3	Yes	SLIGHT	7.3	0	0	0	0.20	0.10	No	0	10	No	No	No
	12/5/96	4	Yes	SLIGHT	7.2	0	0	0	0.20	0.10	No	0	10	No	No	No
<b>13-100-0285</b>																
1992	11/12/91	1	Yes	4	<u>8.2</u>	0	0	0	0		No	0	0	No	No	No
	11/13/91	2	Yes	4	8.0	0	0	0	0		Yes 90	0	0	No	No	No
<b>13-200-0340</b>																
1997	4/3/97	1	Yes	MODER.	<u>8.3</u>	0	0	0	<u>&lt; 0.25</u>	<u>2.00</u>	Yes 2	30	20	PETRO		Yes
	4/3/97	2	Yes	MODER.	<u>8.4</u>	0	0	0	<u>&lt; 0.25</u>	<u>2.00</u>	No	30	20	PETRO		Yes
	5/12/97	3	Yes	STEADY	7.7	0	0	0	<u>&lt; 0.25</u>	<u>3.00</u>	Yes <u>2,200</u>	30	15	PETRO	No	Yes
	5/12/97	4	Yes	STEADY	7.2	0.20	0	0	<u>&lt; 0.25</u>	<u>3.00</u>	No	35	17	PETRO	No	Yes
1998	12/17/97	1	Yes	STEADY	<u>8.2</u>	0	0	0	0	<u>1.00</u>	Yes	20	45	No	BROWN	No
	12/17/97	2	Yes	STEADY	7.9	0	0	<u>0.10</u>	<u>0.50</u>	<u>3.50</u>	No	200	100	OIL/GAS	LOTS	Yes
	1/29/98	3	Yes	LESS	7.2	0	0	0	0	<u>1.00</u>	Yes 20	20	80	No	No	No
	1/29/98	4	Yes	LESS	7.3	0	0	0	0	<u>1.00</u>	No	20	50	UNKNOWN	YELLOWIS	No
1999	11/19/98	3	Yes	2	<u>8.1</u>	0	0	0	0	0.30	No	10	10	No	No	Yes
	11/19/98	4	Yes	2	7.9	0	0	0	0	0.30	No	100	70	No	No	Yes
<b>13-300-0135</b>																
2001	1/16/01	1	Yes	20	7.0	0	0	0	0	<u>7.00</u>	Yes 91	25	20	No	No	No
	1/16/01	2	Yes	20	7.0	0	0	0	<u>0.25</u>	<u>8.00</u>	No	20	30	No	No	No
	3/2/01	3	Yes	5	7.0	0	0	0	0	<u>10.00</u>	No	0	50	No	No	No
	3/2/01	4	Yes	5	7.0	0	0	0	0	<u>10.00</u>	No	0	40		No	No

Outfall Permit Year	Date	Visit #	Flow ?	Flow Rate (gpm)	pH (su)	Chlorine (ppm)	Copper (ppm)	Phenol (ppm)	Detergents (ppm)	Ammonia (ppm)	Fecal Sample (mpn/100ml)	Turbidity (ntu)	Color	Odor?	Surface Scum	Oil Sheen
<b>13-300-0140</b>																
1992	3/3/92	1	Yes	148	<u>8.1</u>	0.05	0	0	0		Yes 170	0	0	No	No	No
	3/4/92	2	Yes	148	<u>8.2</u>	0	0	0	0.15		No	0	0	No	No	No
2001	1/16/01	1	Yes	19	6.0	0	0	0	0	0	No	0	0	No	No	No
	1/16/01	2	Yes	19	6.0	0	0	0	0	0	No	0	0	No	No	No
	3/2/01	3	Yes	10	7.0	0	0	0	0	0	No	0	0	No	No	No
	3/2/01	4	Yes	10	7.0	0	0	0	0	0	No	0	0	No	No	No
<b>13-300-0150</b>																
1992	11/12/91	1	Yes	4	<u>8.4</u>	< 0.10	0	0	<u>0.35</u>		Yes 50	0	0	No	No	No
	11/13/91	2	Yes	4	<u>8.2</u>	<u>0.30</u>	0	0	<u>0.35</u>		No	0	5	No	No	No
1997	2/25/97	1	Yes	5	<u>8.3</u>	0	0	<u>0.10</u>	<u>0.50</u>	0.80	No	50	4	No	No	No
	2/25/97	2	Yes	STEADY	<u>8.5</u>	0	0	<u>0.20</u>	<u>0.50</u>	0.80	No	20	6	No	No	No
1998	4/8/97	3	Yes	10	7.4	0	0	0	<u>0.50</u>	<u>1.00</u>	Yes 126	2	3	No	No	No
	4/8/97	4	Yes	10	7.7	0.10	0	0	<u>0.50</u>	<u>2.00</u>	No	10	5	No	No	No
	11/10/97	1	Yes	12	7.7	0	0	0	<u>1.50</u>	0	No	0	0	No	No	No
	11/10/97	2	Yes	8	7.7	0	0	0	<u>0.75</u>	0.40	No	10	20	No	No	No
	1/5/98	3	Yes	45	7.4	0	0	0	<u>0.75</u>	<u>&lt; 1.00</u>	No	25	30	SLIGHT	No	No
	1/5/98	4	Yes	45	7.8	0	0	0	<u>0.75</u>	<u>2.00</u>	No	20	25	SLIGHT	No	No
2000	2/3/00	3	Yes	1	6.0	<u>0.40</u>	0	0	<u>0.25</u>	0.30	No	0	0	No	No	No
	2/3/00	4	Yes	1	6.5	<u>0.80</u>	0	0	0	0.40	No	0	10	No	No	No
<b>13-300-0155</b>																
2001	1/22/01	1	Yes	30	6.5	0	0	0	0	0	No	0	0	No	No	No
	1/22/01	2	Yes	30	7.0	0	0	0	0	0	No	0	0	No	No	No
	3/26/01	3	Yes	95	7.0	0.20	0	0	0	0	No	0	0	No	No	No
	3/26/01	4	Yes	95	7.0	0	0	0	0	0	No	0	0	No	No	No

Outfall Permit Year	Date	Visit #	Flow ?	Flow Rate (gpm)	pH (su)	Chlorine (ppm)	Copper (ppm)	Phenol (ppm)	Detergents (ppm)	Ammonia (ppm)	Fecal Sample (mpn/100ml)	Turbidity (ntu)	Color	Odor?	Surface Scum	Oil Sheen
<b>13-300-0185</b>																
1992	11/12/91	1	Yes	44	7.6	<u>0.35</u>	0	0	0	0	Yes 0	0	0	No	No	No
	11/13/91	2	Yes	44	7.6	<u>0.30</u>	0	0	0	0	No	0	0	No	No	No
1997	3/12/97	1	Yes	STEADY	<u>8.3</u>	0.10	0	0	<u>&lt; 0.25</u>	<u>&gt; 10.00</u>	Yes < 1	0	1	No	No	No
	3/12/97	2	Yes	STEADY	8.0	0.10	0	0	<u>&lt; 0.25</u>	<u>&gt; 10.00</u>	No	10	1	No	No	No
	4/8/97	3	Yes	STEADY	7.4	0.10	0	0	<u>&lt; 0.25</u>	<u>&gt; 10.00</u>	Yes 14	0	2	No	No	No
	4/8/97	4	Yes	STEADY	7.1	0.10	0	0	<u>&lt; 0.25</u>	<u>&gt; 10.00</u>	No	0	2	No	No	No
1998	10/16/97	1	Yes	60	6.8	0	0	0	0.20	<u>9.00</u>	No	0	0	No	No	No
	10/16/97	2	Yes	60	6.8	0.10	0	0	0.10	<u>7.00</u>	No	0	0	No	No	No
	1/5/98	3	Yes	40	<u>8.2</u>	0	0	0	0.10	<u>8.00</u>	No	0	0	No	No	No
	1/5/98	4	Yes	40	<u>8.3</u>	0	0	0	0.10	<u>10.00</u>	No	0	0	No	No	No
1999	9/10/98	1	Yes	12		0.20	0	<u>0.20</u>	0.10	<u>10.00</u>	No	0	0	No	No	No
	9/10/98	2	Yes	12	7.6	0.15	0	0	0.10	<u>10.00</u>	No	0	0	No	No	No
	12/4/98	3	Yes	10	7.7	0	0	0	<u>0.25</u>	<u>10.00</u>	No	100	70	No	No	No
	12/4/98	4	Yes	10	8.0	0.05	0	0	0	<u>2.00</u>	No	0	40	No	No	No
2000	1/6/00	1	Yes	TRICKLE	7.8	0	0	0	0	0.30	No	0	0	No	No	No
	1/6/00	2	Yes	TRICKLE	8.0	0	0	0	0	0	No	0	0	No	No	No
	2/9/00	3	Yes	3	8.0	<u>2.50</u>	0	0	0	0	No	0	0	No	No	No
<b>13-300-0228</b>																
2001	4/10/01	1	Yes	0.31	7.0	<u>0.80</u>	0	0	0	0	No	0	30	No	No	No
	4/10/01	2	Yes	0.31	7.0	<u>0.40</u>	0	0	0	0	No	0	30	No	No	No
	5/15/01	3	Yes	0.31	7.5	<u>0.60</u>	0	0	0	0	No	0	0	No	No	No
	5/16/01	4	Yes	0.31	7.0	<u>0.80</u>	0	0	<u>1</u>	0.80	No	0	30	No	No	No

Outfall Permit Year	Date	Visit #	Flow ?	Flow Rate (gpm)	pH (su)	Chlorine (ppm)	Copper (ppm)	Phenol (ppm)	Detergents (ppm)	Ammonia (ppm)	Fecal Sample (mpn/100ml)	Turbidity (ntu)	Color	Odor?	Surface Scum	Oil Sheen
<b>13-300-0305</b> 1992	11/11/91	1	Yes	4	7.8	0	0	0	0		No	0	0	No	No	No
	11/12/91	2	Yes	4	7.9	0	0	0	0		Yes 40	0	0	No	No	No
1997	4/3/97	1	Yes	YES	<u>8.5</u>	0.20	0	0	<u>&lt; 0.25</u>	0	No	15	7	No	No	Yes
	4/3/97	2	Yes	STEADY	<u>8.7</u>	0.20	0	0	<u>&lt; 0.25</u>	0	No	10	3	No	No	Yes
	5/12/97	3	Yes	STEADY	7.5	0.10	0	0	<u>&lt; 0.25</u>	<u>2.00</u>	Yes 400	10	5	No	No	No
	5/12/97	4	Yes	STEADY	7.5	0.20	0	0	<u>&lt; 0.25</u>	<u>3.00</u>	No	10	6	No	No	No
1998	12/17/97	1	Yes	INTO PIPE	<u>8.1</u>	0	0	0	0	0	No	0	10	No	No	No
	12/17/97	2	Yes	INTO PIPE	7.9	0.20	0	0	0	0	No	0	10	No	No	No
1999	1/29/98	3	Yes	MEDIUM	7.2	0	0	0	0	0	No	0	10	No	No	No
	1/29/98	4	Yes	MEDIUM	7.5	0	0	0	0	0	No	0	0	No	No	No
	3/19/99	1	Yes	50	<u>8.5</u>	0	0	0	0	0.10	No	0	0	No	No	No
	3/19/99	2	Yes	50	<u>8.5</u>	0	0	0	0	0.10	No	0	0	No	No	No
2001	4/19/99	3	Yes	50	<u>8.4</u>	0	0	0	0	0.10	No	0	0	No	No	No
	4/19/99	4	Yes	50	<u>8.6</u>	0	0	0	0	0.10	No	0	0	No	No	No
2001	3/26/01	3	Yes	0.24	6.5	0	0	0	0	0	No	0	0	No	No	No
	3/26/01	4	Yes	0.24	6.5	<u>0.60</u>	0	0	0	0	No	0	0	No	No	No
<b>13-300-0365</b>																
2001	1/22/01	1	Yes	0.06	6.5	0	0	0	0	0	No	0	0	No	No	No
	1/23/01	2	Yes	0.06	7.0	0	0	0	0	0.50	No	0	95	No	No	No
<b>13-400-0160</b>																
2000	3/15/00	1	Yes	0.16	7.2	<u>0.30</u>	0	0	0	0	No	0	30	No	No	No
	3/15/00	2	Yes	0.16	7.2	0	0	0	0	0	No	0	20	No	No	No
	4/19/00	3	Yes	2	7.3	0	0	0	0	0	No	0	0	No	No	No
	4/19/00	4	Yes	2	7.2	0	0	0	0	0	No	0	20	No	No	No
<b>13-400-0225</b>																
1997	2/19/97	1	Yes	0.20	7.4	0	0	0	0	0	No	0	0	No	No	No
	2/20/97	2	Yes	0.20	7.4	0	0	0	0	0	No	0	0	No	No	No
	3/24/97	3	Yes	0.20	7.0	0.20	0	0	0	0.40	No	0	20	No	No	No
	3/25/97	4	Yes	0.20	7.5	0.20	0	0	<u>0.25</u>	<u>5.50</u>	Yes 2	10	20	SEWAGE		No
<b>13-400-0265</b>																
2000	3/15/00	1	Yes	TOO LOW	7.4	0	0	0	0	0	No	0	0	No	No	No
	3/15/00	2	Yes	TOO LOW	7.4	0	0	0	0	0	No	0	0	No	No	No

Outfall Permit Year	Date	Visit #	Flow ?	Flow Rate (gpm)	pH (su)	Chlorine (ppm)	Copper (ppm)	Phenol (ppm)	Detergents (ppm)	Ammonia (ppm)	Fecal Sample (mpn/100ml)	Turbidity (ntu)	Color	Odor?	Surface Scum	Oil Sheen
<b>13-400-0315</b>																
2000	10/1/99	1	Yes	HEAVY	6.5	0.10	0	0	0.50	2.00	Yes 7,000	0	0	No	No	No
	11/8/99	3	Yes	5	7.4	0.30	0	0	0.50	1.00	Yes 2,300	0	0	No	No	No
	11/8/99	4	Yes	5	7.7	0.20	0	0	0.25	2.00	No	0	0	No	No	No
	11/10/99	5	Yes	HEAVY	7.4	0	0	0	3	10.00	No	0	0	No	No	No
	11/10/99	6	Yes	HEAVY	7.4	0	0	0	3	10.00	No	50	30	No	No	No
	12/17/99	7	Yes	2	7.4	0.20	0	0	0.75	6.00	Yes 35,000	25	0	No	No	No
	12/17/99	8	Yes	2	7.4	0.10	0	0	0.50	5.00	No	0	0	No	No	No
<b>13-400-0325</b>																
2000	12/17/99	3	Yes	0.32	7.6	0	0	0	0	0	No	0	20	No	No	No
	12/17/99	4	Yes	0.32	7.6	0	0	0	0	0	No	0	0	No	No	No
<b>18-100-0700</b>																
1997	6/16/97	3	Yes	2	7.1	0.20	0	0	0.10	2.00	No	0	4			No
	6/16/97	4	Yes	2	7.2	0	0	0	0.10	0.10	No	0	4			No
<b>51-100-0900</b>																
1997	2/20/97	1	Yes	5	7.8	0	0	0	0.10	0	No	0	0	No	No	No
	2/20/97	2	Yes	5	7.9	0	0	0	0	0.05	No	0	0	No	No	No
	3/24/97	3	Yes	3	7.5	0.20	0	0	0.10	7.50	No	0	0	No		No
	3/25/97	4	Yes	3	7.5	0.30	0	0	0.10	1.50	Yes 20	0	0	No		No
1998	1/20/98	1	Yes	20	8.1	0	0	0	0.10	0	No	50	25	No	No	No
	1/20/98	2	Yes	20	8.3	0	0	0	0.10	0	No	50	30	No	No	No
	2/25/98	3	Yes	25	8.4	0	0	0	0.10	0.10	No	50	20	No	No	No
	2/25/98	4	Yes	20	8.2	0	0	0	0.10	0	No	50	20	No	No	No
1999	3/23/99	1	Yes	18	8.4	0.05	0	0	0	0	No	0	0	No	No	No
	3/23/99	2	Yes	15	8.3	0	0	0	0	0	No	0	0	No	No	No
	5/10/99	3	Yes	30	8.6	0	0	0	0	0	No	0	0	No	No	No
	5/10/99	4	Yes	30	8.7	0	0	0	0	0	No	0	0	No	No	No
2000	9/16/99	1	Yes	2	6.5	0.30	0	0	0	0	No	0	0	No	No	No
	9/16/99	2	Yes	2	6.5	0	0	0	0	0	No	0	0	No	No	No
	10/18/99	3	Yes	2	6.0	0	0	0	0	0	No	0	0	No	No	No
	10/18/99	4	Yes	2	6.0	0	0	0	0	0	No	0	0	No	No	No

Outfall Permit Year	Date	Visit #	Flow ?	Flow Rate (gpm)	pH (su)	Chlorine (ppm)	Copper (ppm)	Phenol (ppm)	Detergents (ppm)	Ammonia (ppm)	Fecal Sample (mpn/100ml)	Turbidity (ntu)	Color	Odor?	Surface Scum	Oil Sheen
<b>53-100-0045</b> 1992	11/20/91	1	Yes	4	8.0	0.15	0	0	0		Yes 130	0	0	No	No	No
	11/20/91	2	Yes	4	7.9	< 0.10	0	0	0		No	0	10	No	No	No
1997	5/7/97	1	Yes	10	7.7	0	0	0	< 0.25	0.10	No	10	4	No	No	No
	5/7/97	2	Yes	10	7.4	0	0	0	< 0.25	0.10	No	10	3	No	No	No
1999	6/20/97	3	Yes	4	7.5	0	0	0	0	0	No	20	8	No	No	No
	6/20/97	4	Yes	2	7.2	0	0	0	0	0.20	No	10	5	No	No	No
	3/22/99	1	Yes	19	7.5	0	0	0	0	0.10	No	0	0	No	No	No
	3/22/99	2	Yes	19	7.6	0	0	0	0	0.10	No	0	0	No	No	No
	5/4/99	3	Yes	3	7.0	0.10	0	0	0	0	No	0	0	No	No	No
	5/4/99	4	Yes	3	6.5	0.10	0	0	0	0	No	0	35	No	No	No
2000	9/16/99	1	Yes	0.80	6.5	0.30	0	0	0	0	No	0	0	No	No	No
	9/16/99	2	Yes	0.80	7.0	0.30	0	0	0	0.30	No	0	0	No	No	No
2001	10/18/99	3	Yes	1	6.0	0	0	0	0	0	No	0	0	No	No	No
	10/18/99	4	Yes	2	6.0	0	0	0	0	0	No	0	0	No	No	No
	8/16/00	1	Yes	2	7.6	0.10	0	0	0	0.60	No	0	0	No	No	No
	8/16/00	2	Yes	1	7.8	0.20	0	0	0	0.30	No	0	0	No	No	No
	10/4/00	3	Yes	4	7.8	0	0	0	0	0	No	0	0	No	No	No
	10/4/00	4	Yes	3	8.0	0.60	0	0	0	0	No	0	0	No	No	No
<b>53-100-0065</b> 1992	11/20/91	1	Yes	4	7.8	0.25	0	0	0		Yes 0	0	0	No	No	No
	11/20/91	2	Yes	4	7.7	1.00	0	0	0		No	0	0	No	No	No
1997	5/7/97	1	Yes	10	7.7	3.50	0	0	< 0.25	0	No	5	5	No	No	No
	5/7/97	2	Yes	16	7.9	2.50	0	0	0	0	No	15	5	No	No	No
<b>53-100-0075</b> 1992	11/20/91	1	Yes	4	8.3	< 0.10	0	0	0		Yes 530	0	0	No	No	No
	11/20/91	2	Yes	4	8.4	0	0	0	0		No	0	15	No	No	No
1997	10/31/96	1	Yes	5	8.1	0	0	0	0.10		Yes 36	0	0	No	No	No
	11/1/96	2	Yes	5	8.1	0	0	0	0.10		No	0	10	No	No	No
	12/3/96	3	Yes	STEADY	7.9	0	0	0	0.20	0.10	No	0	0	No	No	No
	12/4/96	4	Yes	STEADY	7.9	0	0	0	0.25	0.10	No	0	0	No	No	No

Outfall Permit Year	Date	Visit #	Flow ?	Flow Rate (gpm)	pH (su)	Chlorine (ppm)	Copper (ppm)	Phenol (ppm)	Detergents (ppm)	Ammonia (ppm)	Fecal Sample (mpn/100ml)	Turbidity (ntu)	Color	Odor?	Surface Scum	Oil Sheen
<b>53-100-0085</b> 1992	11/20/91	1	Yes	4	8.0	0	0	0	0		No	0	10	No	No	No
	11/20/91	2	Yes	4	8.0	0	0	0	0		No	0	0	No	No	No
1997	5/6/97	1	Yes	STEADY	7.3	0	0	0	< 0.25	0.20	No	5	4	No	No	No
	5/6/97	2	Yes	STEADY	7.7	0.20	0	0	< 0.25	0.20	No	5	3	No	No	No
	6/20/97	3	Yes	STEADY	7.4	0	0	0	0	0.10	No	25	7	No		No
1998	6/20/97	4	Yes	STEADY	7.2	0.30	0	0	0	1.00	No	25	7	No		No
	5/14/98	1	Yes	0.10	8.5	0.10	0	0	0	0.30	No	0	20	No	No	No
	5/14/98	2	Yes	0.10	7.7	0.10	0	0	0	0.10	No	0	15	No	No	No
	6/25/98	3	Yes	3	7.6	0	0	0	0	0.10	No	0	12	No	BROWN	No
	6/25/98	4	Yes	3	7.5	0	0	0	0	0.30	No	0	10	No	BROWN	No
<b>53-100-0090</b>																
1997	5/7/97	1	Yes	24	7.8	0	0	0	< 0.25	0	No	15	5	No	No	No
	5/7/97	2	Yes	MODERA	7.7	0.10	0	0		0.20	No	5	3	No	No	No
	6/20/97	3	Yes	MODERA	6.9	0	0	0	0	0.10	No	10	5	No	No	No
1998	6/20/97	4	Yes	MODERA	7.8	0.30	0	0	0	0.80	No	20	5	No	No	No
	5/14/98	1	Yes	0.20	8.2	0.10	0	0.10	0	0.10	No	0	15	MUSTY	No	No
	5/14/98	2	Yes	0.20	8.2	0.10	0	0	0	0.10	No	25	30	MUSTY	No	No
	6/25/98	3	Yes	0.20	7.9	0	0	0	0	0.10	No	10	10	No	No	No
	6/25/98	4	Yes	0.20	7.8	0	0	0	0.20	0.30	No	10	15	No	GRAY	No
<b>53-200-0125</b>																
1992	11/20/91	1	Yes	4	7.5	< 0.10	0	0	0		No	0	0	No	No	No
	11/20/91	2	Yes	4	7.6	< 0.10	0	0	0		No	0	0	No	No	No
<b>53-200-0160</b>																
1992	1/30/92	1	Yes	4	8.3	0	0	0	0		No	0	0	No	No	No
	1/30/92	2	Yes	4	8.4	0	0	0	0		Yes 50	0	0	No	No	No
<b>53-200-0170</b>																
1992	1/30/92	1	Yes	4	7.9	0	0	0	0		No	0	0	No	No	No
	1/30/92	2	Yes	4	7.9	0	0	0	0		Yes 0	0	0	No	No	No

<b>Outfall Permit Year</b>	<i>Date</i>	<i>Visit #</i>	<i>Flow ?</i>	<i>Flow Rate (gpm)</i>	<i>pH (su)</i>	<i>Chlorine (ppm)</i>	<i>Copper (ppm)</i>	<i>Phenol (ppm)</i>	<i>Detergents (ppm)</i>	<i>Ammonia (ppm)</i>	<i>Fecal Sample (mpn/100ml)</i>	<i>Turbidity (ntu)</i>	<i>Color</i>	<i>Odor?</i>	<i>Surface Scum</i>	<i>Oil Sheen</i>
<b>53-200-0240</b>																
1992	1/30/92	1	Yes	17	7.7	0	0	0	0		No	0	0	No	No	No
	1/30/92	2	Yes	17	8.0	0	0	0	0		Yes 10	< 50	5	No	No	No
1997	2/19/97	1	Yes	0.25	7.6	0	0	0	0	0	No	0	0	No	No	No
	2/20/97	2	Yes	0.25	7.4	0	0	0	0	0.30	No	0	0	No	No	No
	3/24/97	3	Yes	8	7.4	0	0	0	0.10	0.10	No	0	20	No		No
	3/25/97	4	Yes	8	7.3	0.10	0	0	0.10	0	No	0	20	No		No
<b>53-400-0100</b>																
2000	4/7/00	4	Yes	0.01	7.8	<u>0.55</u>	0	0	0	0	No	0	0	No	No	No
<b>54-500-0005</b>																
1992	1/30/92	1	Yes	4	7.6	0	0	0	0		No	0	8	No	No	No
	1/30/92	2	Yes	4	7.7	0	0	0	0		Yes 0	0	0	No	No	No
<b>71-400-0600</b>																
1999	3/22/99	1	Yes	10	7.0	0	0	0	0	0	No	0	0	No	No	No
	3/22/99	2	Yes	10	7.2	0.10	0	0	0	0	No	0	0	No	No	No
	5/4/99	3	Yes	2	7.0	0	0	0	0	0	No	0	40	No	No	No
	5/4/99	4	Yes	2	6.5	0.10	0	0	0	0.30	No	0	10	No	No	No
<b>79-100-0365</b>																
1997	5/5/97	1	Yes	25	7.0	0	0	0	0.10	<u>1.50</u>	Yes 120	10	0	No	No	No
	5/5/97	2	Yes	30	7.0	0	0	0	0.10	0.40	No	0	0	No		No
	6/20/97	3	Yes	25	7.1	0	0	0	0.10	0.10	No	0	4	No	No	No
	6/20/97	4	Yes	25	7.2	0	0	0	0.10	0	No	0	4	No	No	No
1998	1/21/98	1	Yes	1	<u>8.6</u>	0	0	0	0.10	0	No	0	0	No	No	No
	1/21/98	2	Yes	1	<u>8.4</u>	0	0	0	0.10	0	No	0	0	No	No	No
	2/24/98	3	Yes	10	<u>8.7</u>	0	0	0	0.10	0	No	50	30	No	No	No
	2/24/98	4	Yes	10	<u>8.2</u>	0	0	0	0.20	0	No	50	30	No	No	No

<b>Outfall Permit Year</b>	<i>Date</i>	<i>Visit #</i>	<i>Flow ?</i>	<i>Flow Rate (gpm)</i>	<i>pH (su)</i>	<i>Chlorine (ppm)</i>	<i>Copper (ppm)</i>	<i>Phenol (ppm)</i>	<i>Detergents (ppm)</i>	<i>Ammonia (ppm)</i>	<i>Fecal Sample (mpn/100ml)</i>	<i>Turbidity (ntu)</i>	<i>Color</i>	<i>Odor?</i>	<i>Surface Scum</i>	<i>Oil Sheen</i>	
<b>79-100-0380</b> 1997	5/5/97	1	Yes	2	7.4	0	0	0	0.10	0.40	No	0	0	No	No	No	
	5/5/97	2	Yes	2	7.4	0	0	0	0.10	0	No	0	10	SAWDUST	No	Yes	
	6/20/97	3	Yes	2	6.9	0.10	0	0	0.10	<u>4.00</u>	No	10	10	No		Yes	
	6/20/97	4	Yes	2	7.1	0.20	0	0	0.10	0.30	No	0	10	YES		Yes	
1998	1/21/98	1	Yes	1	<u>8.3</u>	0	0	0	0.10	0.60	No	0	0	FISH	No	No	
	1/21/98	2	Yes	1	<u>8.2</u>	0	0	0	0.10	0.10	No	0	0	FISH	No	No	
	2/24/98	3	Yes	5	<u>8.1</u>	0.10	0	0	0.10	0	No	50	5	No		No	
	2/24/98	4	Yes	5	<u>8.2</u>	0	0	0	0.10	0	No	50	5	No		No	
1999	8/25/98	1	Yes	3	<u>8.1</u>	0	0	0	0.20	0.10	No	0	0	FISH	No	No	
	8/26/98	2	Yes	4	8.0	0	0	0	0.20	0.10	No	0	0	FISH	No	No	
<b>79-100-0400</b> 1997	5/2/97	1	Yes	2	8.0	0	0	0	0.10	0	No	0	0	No	No	No	
	5/2/97	2	Yes	2	<u>8.1</u>	0	0	0	0.10	0	No	0	0	No	No	No	
	6/16/97	3	Yes	3	7.4	0	0	0	0.10	0	No	0	4	No	No	No	
	6/16/97	4	Yes	3	7.2	0.10	0	0	0.10	0	No	0	4	No	No	No	
<b>79-200-0345</b> 1997	5/2/97	1	Yes	3	6.4	0	0	<u>0.20</u>	0.10	<u>&gt; 10.00</u>	No	0	0	No	No	No	
	5/2/97	2	Yes	3	6.8	0	0	<u>0.10</u>	<u>0.25</u>	<u>&gt; 10.00</u>	No	0	0	No	No	No	
	1998	1/21/98	2	Yes	1	<u>8.3</u>	0	0	0	0.10	<u>&gt; 10.00</u>	No	0	0	No	No	No
		2/24/98	3	Yes	3	7.7	0	0	0	0.20	<u>&gt; 10.00</u>	No	100	40	No	No	No
		2/24/98	4	Yes	2	<u>8.1</u>	0	0	0	0.20	<u>&gt; 10.00</u>	No	50	30	No	No	No

Outfall Permit Year	Date	Visit #	Flow ?	Flow Rate (gpm)	pH (su)	Chlorine (ppm)	Copper (ppm)	Phenol (ppm)	Detergents (ppm)	Ammonia (ppm)	Fecal Sample (mpn/100ml)	Turbidity (ntu)	Color	Odor?	Surface Scum	Oil Sheen
<b>79-400-0340</b>																
1997	5/2/97	1	Yes	10	6.7	0	<u>0.20</u>		<u>0.50</u>	<u>&gt; 10.00</u>	Yes < 1	0	0	No		No
	5/2/97	2	Yes	15	6.8	0	<u>0.10</u>		<u>0.40</u>	<u>&gt; 10.00</u>	No	0	0	No		No
	6/16/97	3	Yes	15	6.5	0.10	<u>0.10</u>	0	0.10	<u>&gt; 10.00</u>	No	0	4	No		No
	6/16/97	4	Yes	10	6.4	0.20	<u>0.10</u>	0	<u>0.25</u>	<u>&gt; 10.00</u>	No	0	4	No		No
1998	1/21/98	1	Yes	25	7.4	0	0	0	0.20	<u>&gt; 10.00</u>	Yes < 1	0	0	No	No	No
	1/21/98	2	Yes	25	7.8	0	0	0	0.20	<u>&gt; 10.00</u>	No	0	0	No	No	No
	2/24/98	3	Yes	20	7.4	0	<u>0.20</u>	0	0.20	<u>&gt; 10.00</u>	No	50	0	No	No	No
	2/24/98	4	Yes	20	7.8	0	<u>0.10</u>	0	0.20	<u>&gt; 10.00</u>	No	50	0	No	FOAM	No
1999	8/25/98	1	Yes	3	8.0	0.10	<u>0.10</u>	0	0.20	<u>10.00</u>	No	10	0	No	No	No
	8/26/98	2	Yes	3	<u>8.2</u>	0.10	<u>0.10</u>	0	0.20	<u>10.00</u>	No	0	0	No	No	No
	12/4/98	3	Yes	3	6.8	0.20	<u>0.20</u>	<u>0.20</u>	<u>0.25</u>		No	0	0	No	No	No
	12/4/98	4	Yes	3	6.5	0.10	<u>0.20</u>	<u>0.20</u>	<u>0.25</u>		No	0	0	No	No	No
2000	10/1/99	1	Yes	3	6.5	0	0		<u>0.50</u>		No	0	0	No	No	No
	10/1/99	2	Yes	3	7.0	0	0		<u>0.50</u>		No	0	0	No	No	No
	11/8/99	3	Yes	4	7.2	0.20	<u>0.20</u>		<u>0.25</u>		No	0	0	No	No	No
	11/8/99	4	Yes	4	7.2	0.10	<u>0.20</u>		<u>0.25</u>		No	0	0	No	No	No
2001	8/15/00	1	Yes	2	7.0	0	0	0	0	0	No	0	30	No	No	No
	8/15/00	2	Yes	2	7.2	<u>0.40</u>	<u>0.20</u>	0	0	0	No	0	0	No	No	No
	10/4/00	3	Yes	4	7.0	<u>0.40</u>	<u>0.20</u>	0	<u>0.25</u>	0	No	0	20	No	No	No
	10/4/00	4	Yes	3	7.0	0	0	0	<u>0.25</u>	0	No	0	20	No	No	No
<b>79-400-0375</b>																
1997	5/5/97	1	Yes	10	7.2	0	0	0	0.10	<u>1.00</u>	Yes 36	0	0	SLIGHT		No
	5/5/97	2	Yes	10	7.0	0	0	0	<u>0.25</u>	<u>2.00</u>	No	0	0	No		No
	6/20/97	3	Yes	2	6.5	0	0	0	0.10	<u>10.00</u>	No	50	12	MUSTY		Yes
	6/20/97	4	Yes	2	6.7	0	0	0	0.10	<u>4.00</u>	No	50	12	MUSTY		Yes
1998	1/21/98	1	Yes	3	<u>8.4</u>	0	0	0	0.10	0	No	150	50	No	No	No
	1/21/98	2	Yes	3	<u>8.6</u>	0	0	0	0.10	0	No	50	50	No	No	No
	2/24/98	3	Yes	2	<u>8.2</u>	0	0	0	0.10	0	No	50	15	No	No	No
	2/24/98	4	Yes	2	<u>8.1</u>	0	0	0	0.10	0	No	50	15	No	No	No

Outfall Permit Year	Date	Visit #	Flow ?	Flow Rate (gpm)	pH (su)	Chlorine (ppm)	Copper (ppm)	Phenol (ppm)	Detergents (ppm)	Ammonia (ppm)	Fecal Sample (mpn/100ml)	Turbidity (ntu)	Color	Odor?	Surface Scum	Oil Sheen
79-400-0385 1997	5/5/97	1	Yes	5	7.6	0.10	0	0	0.10	0	No	50	0	No		No
	5/5/97	2	Yes	5	7.7	0	0	0	0.10	0	No	0	0	No		No
	6/20/97	3	Yes	5	7.2	0	0	0	0.10	0.10	No	10	10	FISHY		No
1998	6/20/97	4	Yes	3	7.0	<u>0.30</u>	0	0	<u>0.25</u>	0.30	No	10	10	FISHY		Yes
	1/21/98	1	Yes	20	<u>8.3</u>	0	0	0	0.10	0.20	No	0	0	No	No	No
	1/21/98	2	Yes	20	<u>8.5</u>	0	0	0	0.10	0	No	0	0	No	No	No
	2/24/98	3	Yes	3	8.0	0	0	0	0.10	0	No	25	10	No	No	No
1999	2/24/98	4	Yes	3	<u>8.7</u>	0	0	0	0.10	0	No	25	10	No	No	No
	8/25/98	1	Yes	5	<u>8.1</u>	0	0	0	0.20	0	No	0	0	No	No	No
	8/25/98	2	Yes	5	<u>8.2</u>	0	0	0	0.20	0.10	No	0	0	No	No	No
2000	11/19/98	3	Yes	VERY LO	7.7	0.10	0	0	0	0	No	0	20	No		No
	11/19/98	4	Yes	VERY LO	<u>8.3</u>	0.20	0	0	0	0	No	0	40	No	BROWN FC	No
	9/23/99	1	Yes	5	7.0	<u>0.40</u>	0	0	0	0	No	0		No	No	No
	9/23/99	2	Yes	5	7.0	0.20	0	0	0	0	No	0		No	No	No
	10/25/99	3	Yes	5	6.0	0	0	0	0	0	No	0	0	No	No	No
	10/25/99	4	Yes	5	6.0	<u>0.40</u>	0	0	0	0	No	0	0	No	No	No

Shaded rows represent samples which contained elevated levels for at least 1 sampled parameter.

Elevated readings have been underlined.

Below is a listing of sample parameters and their elevated reading criteria:

- pH <= 6 or >8 su
- Chlorine >=0.3 ppm
- Copper >=0.1 ppm
- Phenol >=0.1 ppm
- Detergents >=0.25 ppm
- Ammonia >=1 ppm
- Fecal Sample >=200 mpn/100 ml

Record Selection Criteria: SELECT \* FROM qryAllData WHERE ((CollectionDate) < #07/01/01#) and (((flow)=Yes))